

Harnett County Environmental Health**EXISTING SYSTEM APPROVAL**☒ Existing System Approval

- ☐ Site modification (e.g., storage shed) or footprint addition with no DDF or wastewater strength increase
- ☐ Reconnection when the proposed facility is in the same footprint as existing/previous facility

☒ Construction Authorization/Notice of Intent to Construct

[issued for reconnection when the proposed facility is not in the same footprint as existing/previous facility pursuant to Session Law 2023-77, Section 5.(c)]
[certified inspectors are not authorized to approve reconnections outside of footprint pursuant to Session Law 2023-77, Section 5.(c)]

Applicant: Daron StoneMailing Address: 1012 Purfoy RdCity: Fuquay VarinaState: NCZip: 27526Phone #: 919-422-8682Email: Daronstone74@gmail.comOwner: HAIR STUART ADAMS SR & HAIR CATHY TAYLORMailing Address: 1012 Purfoy RdCity: Fuquay VarinaState: NCZip: 27521Phone #: 919-524-9615Email: Stuarthair@msn.comPIN/Lot Identifier: 0664-67-1590.000Property Location/Address: 904 PURFOY RD FUQUAY VARINA, NC 27526Facility Type: ☐ House/Modular ☒ Mobile/Manufactured Home ☐ Business ☐ Other: _____Operation Permit/ATO #: N/A Design Daily Flow: 360 GPDNumber of Bedrooms: 3Max # Occupants: 6

Other: _____

Wastewater Strength: ☒ Domestic ☐ High Strength ☐ Industrial Process WastewaterWater Supply: ☐ Private well ☐ Public well ☐ Shared well ☒ Municipal Supply ☐ Spring ☐ Other: _____Proposed Property Improvement: Demolition of original build and replacing with a 32' x 56' DW.

All the following must be checked for approval:

- ☒ No current or past uncorrected malfunction of the system as described in 15A NCAC 18E .1303(a)(2)
- ☒ DDF and wastewater strength for the proposed facility or site modification do not exceed that of the existing system
- ☒ Proposed facility or site modification meets the setbacks in Section .0600 of 15A NCAC 18E

Approval Conditions: No Cutting or Grading of Soil In Septic or Septic Repair Area.No Foundation or Gutter Drains to be Directed Towards Septic System.Inspector's Printed Name: Ren LevoczInspector Certification #: 3345Inspector's Signature: Date: 9-23-25***The existing system approval expires one year after the date of issuance.*******See attached site sketch****


EXISTING SYSTEM APPROVAL SITE SKETCH

Operation Permit/ATO #: N/A

PIN/Lot Identifier: 0664-67-1590.000

Owner: HAIR STUART ADAMS SR & HAIR CATHY TAYLOR

Property Location/Address: 904 PURFOY RD FUQUAY VARINA, NC 27526



**Include the existing and proposed structures and applicable setbacks.*