



Harnett  
COUNTY  
NORTH CAROLINA

HARNEET COUNTY ENVIRONMENTAL HEALTH

File/Permit #: BRES2509-0066

CDP #: \_\_\_\_\_

IMPROVEMENT PERMIT (IP)

New

Expansion

Repair

System Relocation

Change of Use

Owner: \_\_\_\_\_

Applicant: \_\_\_\_\_

Property Location: \_\_\_\_\_

PIN/Lot Identifier: \_\_\_\_\_

Subdivision: \_\_\_\_\_

Lot #: \_\_\_\_\_ Block: \_\_\_\_\_ Section: \_\_\_\_\_

Facility Type: \_\_\_\_\_ Number of bedrooms: \_\_\_\_\_ Number of Occupants: \_\_\_\_\_ Other: \_\_\_\_\_

Design Daily Flow: \_\_\_\_\_ GPD LTAR (Initial): \_\_\_\_\_ gpd/ft<sup>2</sup> LTAR (Repair): \_\_\_\_\_ gpd/ft<sup>2</sup>

Wastewater System Type: \_\_\_\_\_ (Initial)

Pump Required:  Yes  No  May be required Usable Depth to Limiting Condition (Initial): \_\_\_\_\_

Wastewater System Type: \_\_\_\_\_ (Repair)

Pump Required:  Yes  No  May be required Usable Depth to Limiting Condition (Repair): \_\_\_\_\_

Effluent Standard:  DSE  HSE  Other: \_\_\_\_\_ Type of Water Supply:  Private well  Municipal Supply  Other: \_\_\_\_\_

Permit conditions:

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. *This permit is subject to revocation if the site plan, plat, or the intended use changes.* The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized Agent's Printed Name: Ren Levocz

Date: 11/21/2025

Authorized Agent's Signature: \_\_\_\_\_

Expiration Date: \_\_\_\_\_

CONSTRUCTION AUTHORIZATION (CA)

New

Expansion

Repair

System Relocation

Change of Use

Owner: CANCIO VICKI S

Applicant: CANCIO VICKI S

Property Location: 1822 PURFOY RD FUQUAY VARINA, NC 27526

PIN/Lot Identifier: 0665-51-8833.000

Subdivision: \_\_\_\_\_

Lot #: LOT#7 Block: \_\_\_\_\_ Section: \_\_\_\_\_

Facility Type: Ex. SFD Number of bedrooms: 3 Number of Occupants: 6 Other: \_\_\_\_\_

Design Daily Flow: 360 GPD LTAR: 35 gpd/ft<sup>2</sup>

Effluent Standard:  DSE  HSE  Other: \_\_\_\_\_ Type of Water Supply:  Private well  Municipal Supply  Other: \_\_\_\_\_

Installation Requirements/Conditions

Wastewater System Type: Ex. Conventional System

Pump Required:  Yes  No  May be required

Septic Tank Size: Ex. 1,000 gallons Total Trench Length: 340' feet

Trench Spacing: 9' feet on center

Pump Tank Size: \_\_\_\_\_ gallons Maximum Trench Depth: 18"- 20" inches Soil Cover: 6" inches

Trench Width: 36" inches Distribution Method:  Serial  D-Box or Parallel  Pressure Manifold  Other: \_\_\_\_\_

Artificial Drainage Required: Yes  No  If yes, please specify details: \_\_\_\_\_

Management Entity Required:  Yes  No Minimum O&M Requirements: \_\_\_\_\_

Permit conditions:

Will be Cutting and Removing 50' from Each Existing Conventional Septic Line, and Relocating the Footage to a New Additional Line using 25% Reduction Product as seen on Site Sketch. Remove Existing Pergola and concrete footings due to setback encroachments on septic system

The requirements of 15A NCAC 18E are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached site sketch. *This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes.* The Construction Authorization shall not be affected by a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of 15A NCAC 18E, or 15A NCAC 18A .1900, as applicable, and to the conditions of this permit.

Authorized Agent's Printed Name: Ren Levocz

Date: 11/21/25

Authorized Agent's Signature:

Expiration Date: 11/21/2030

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

\*See attached site sketch

# Harnett County Environmental Health

PIN 0665-51-8833.000

Permit Number

BRES2509-0066

CANCIO VICKI S

Applicant's Name  
Ren Levocz

Authorized State Agent

## SITE SKETCH

LOT#7

Subdivision/Section/Lot Number  
11/21/2025

Date

System components represent approximate contours only. The contractor must flag the system prior to beginning the installation to ensure that the proper grade is maintained.

Scale = NTS

