



Permit Reviews

Harnett County

Permit Number: BRES2510-0006

Description: 11x19 residential sunroom

Applied: 10/2/2025

Approved:

Site Address: 58 NAVAHO TRL

Issued:

Finalized:

City, State Zip Code: SANFORD, NC 27332

Status: RECEIVED

Applicant: WISOCKI SAMANTHA L

Parent Permit:

Owner: WISOCKI SAMANTHA L

Parent Project:

Contractor: WISOCKI SAMANTHA L

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: 1ST PLAN REVIEW						
10/13/2025		10/27/2025	ENVIRONMENTAL	EH Bucket		
Notes:						
Review Group: AUTO						
10/2/2025	10/2/2025	10/3/2025	CENTRAL PERMITTING INTAKE	CP Bucket	APPROVED	
Notes:						
10/2/2025	10/6/2025	10/7/2025	RESIDENTIAL BUILDING	Brad Sutton	DISAPPROVED	in attachments
Notes: provide wall framing/bracing method Provide header sizes over opening for windows/doors provide roof covering material. Roof slope is less than 2:12						
10/6/2025			RESIDENTIAL BUILDING	Building Bucket		
Notes:						