



# Permit Inspections

## Harnett County

Permit Number: **BRES2510-0007**

Description: **16 x 14 deck**

Applied: **10/2/2025**

Approved: **10/10/2025**

Site Address: **75 WATERVILLE WAY**

Issued: **10/10/2025**

Finalized: **11/21/2025**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **FINALED**

Applicant: **Davis Home Improvement and Restoration LLC**

Parent Permit:

Owner: **HYNNEMAN TRACY**

Parent Project:

Contractor: **Davis Home Improvement and Restoration LLC**

Details:

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	10/29/2025	10/29/2025	FOOTING	Daniel L Floyd	APPROVED	

Notes:

	11/18/2025	11/18/2025	FINAL**	Deen Taylor	DISAPPROVED	
--	------------	------------	---------	-------------	-------------	--

Notes:

Stair handrail horizontal grip width cannot exceed 3 1/2 inches.

	11/21/2025	11/21/2025	FINAL**	Daniel L Floyd	APPROVED	
--	------------	------------	---------	----------------	----------	--

Notes:

Previous item corrected