


(PARTIALLY) ENCLOSED GABLE END BUILDING MAXIMUM 30' WIDE X 16' EAVE HEIGHT WITH BOX FRAME / (UP TO) 145 M.P.H. WIND ZONE - 35 P.S.F. SNOW LOAD FOR:

Aaron Costello 1046 Lipscomb Road Angier NC 27501

ISSUE DATE: 09/25/2025








THESE PLANS HAVE BEEN PROPERLY EXAMINED BY THE UNDERSIGNED.I DETERMINED THAT THEY COMPLY WITH EXISTING LOCAL NORTH CAROLINA CODES AND ARE APPROPRIATE FOR USE IN THIS AREA

NOTE: THESE DRAWINGS ARE VALID FOR (1) CALENDER YEAR AFTER THE ISSUE DATE LISTED ON THIS SHEET.

SHEET INDEX

SHEET NUMBER	SHEET TITLE
so ———	SEALED COVER SHEET
S2 ———	Bitition in BEA
S3 ———	GENERAL NOTES AND SPECIFICATIONS
S4 ———	SIDE AND END ELEVATIONS
S5 ———	TYPICAL RAFTER / COLUMN FRAME SECTIONS
S5A ———	TYPICAL RAFTER / COLUMN FRAME SECTIONS
S5B ———	TYPICAL RAFTER / COLUMN FRAME AND SIDE FRAMING SECTION
S6 ———	COLUMN CONNECTION DETAILS (LACED COLUMN)
S6A	COLUMN CONNECTION DETAILS
307	(DOUBLE AND SINGLE COLUMN)
S6B ———	COLUMN CONNECTION DETAILS
	(LACED COLUMN)
S6C	COLUMN CONNECTION DETAILS
	(DOUBLE AND SINGLE COLUMN)
S7 ———	BASE RAIL ANCHORAGE
S7A	BASE RAIL ANCHORAGE
S7B	BASE RAIL ANCHORAGE
S7C ———	BASE RAIL ANCHORAGE
S7D ———	BASE RAIL ANCHORAGE
S7E	BASE RAIL ANCHORAGE
S7F ———	BASE RAIL ANCHORAGE
S7G ———	BASE RAIL ANCHORAGE
	BASE RAIL ANCHORAGE
S8 ———	BASE RAIL ANCHORAGE
S8A	BASE RAIL ANCHORAGE
S9 ———	TYPICAL END WALL OPENINGS
	FRAMING SECTIONS
S9A ———	TYPICAL SIDE WALL OPENINGS FRAMING SECTIONS
S10 ———	CONNECTION DETAILS
S11 ———	CONNECTION DETAILS
S12 ———	CONNECTION DETAILS
S13 ———	CONNECTION DETAILS
S14 ———	CONNECTION DETAILS
S15 ———	LEAN-TO OPTIONS
S15A	LEAN-TO CONNECTION DETAILS
S15B	LEAN-TO CONNECTION DETAILS
S15C ———	LEAN-TO CONNECTION DETAILS
S16 ———	VERTICAL ROOF / SIDING OPTION END AND SIDE ELEVATION
S16A	VERTICAL ROOF / SIDING OPTION END SECTION
S16B	VERTICAL ROOF / SIDING OPTION SIDE SECTION
S17 ———	SIDE WALL HEADER OPTIONS
S17A	END WALL HEADER OPTIONS



JCMT
ASSOCIATES, PLLC
PO BOX 27

PO BOX 27 Pilot Mountain, NC 28641 828-310-7160 Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS **PROJECT NO:** 0725-0864

DATE: 09/25/25

DESIGN LOADS:				
IMPORTANCE FACTORS	SNOW (1	1w) 1.00 1s) 1.00 1e) 1.00		
DEAD LOADS	ROOF ROOF COLLATERAL	13 P.S.F. 0 P.S.F.		
LIVE LOADS	ROOF	<u>20</u> P.S.F.		
GROUND SNOW LOAD:		15 P.S.F. * DRIFT LOAD HAS NOT BEEN CALCULATED		
WIND LOAD:	BASIC WIND SPEED EXPOSURE CATAGORY			
SEISMIC DESIGN CATAGORY				
PROVIDE THE FOLLOWING SEISMIC DESIGN PARAMETERS:				
OCCUPANCY CATEGORY				
SPECTRAL RESPONSE ACCELERATION Ss 12.6 %g S1 6.3 %g				
SITE CLASSIFICATION FIELD TEST . PRESUMPTIVE . HISTORICAL DATA				
BASIC STRUCTURAL SYSTEM (CHECK ONE)				
BEARING WALL DUAL W/ SPECTRAL MOMENT FRAME BUILDING FRAME DUAL W/ INTERMEDIATE R/C OR SPECIAL STEEL MOMENT FRAME INVERTED PENDULUM				
ANALYSIS PROCEDURE SIMPLIFIEDX EQUIVALANT LATERAL FORCE MODAL				
LATERAL DESIGN CONTROL? EARTHQUAKEX WIND				
SOIL BEARING CAPACITIES: PRESUMPTIVE BEARING CAPACITIES: 1,500 P.S.F.				

GENERAL NOTES:

- 1. MAX FRAME SPACING SHALL BE 60"oc UNLESS NOTED OTHERWISE.
- 2. MAX. END-WALL COLUMN SPACING SHALL BE 60" oc UNLESS NOTED OTHERWISE.
- 3. TUBE MATERIAL SHALL BE 2-1/2" x 2-1/2" x 14gg. 50 K.S.I. MIN. UNLESS NOTED OTHERWISE.
- 4. ALL FASTENERS SHALL BE (2) #12 SELF TAPPING AT 9"o.c. UNLESS NOTED OTHERWISE.
- 5. 1,500 P.S.F. ASSUMED BEARING CAPACITY UNLESS NOTED OTHERWISE.
- 6. THESE DRAWINGS ARE NOT FOR SLEEPING QUARTERS.
- 7. THIS DESIGN AND DRAWINGS MEET THE REQUIRMENTS OF THE 2021IBC.

WISE. CARO SESSION SEAL 27874

VGINEE 27874

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS


PROJECT NO: 0725-0864


DATE: 09/25/25


BOX EVE FRAME RAFTER STURCTURE ROLL-UP DOOR PERSONNEL DOOR (AS APPLICABLE) (AS APPLICABLE) 6" (TYP.) FLASHING W < 30'-0" MAXIMUM RAFTER SPAN TYPICAL END ELEVATION **WINDOW** (AS APPLICABLE) 6" (TYP.) **FLASHING** LENGTH VARIES DEPENDING ON NUMBER AND SPACING OF RAFTERS TYPICAL SIDE ELEVATION 09/25/2025 DRAWN BY: PROJECT NO: **Aaron Costello** 0725-0864 BKS 1046 Lipscomb Road **PO BOX 27** DATE: SHEET NO: Angier NC 27501 Pilot Mountain, NC 28641 09/25/25 **S4**

828-310-7160










S6 SCALE: 3/4" = 1'-0"






ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641

828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS **PROJECT NO:** 0725-0864

DATE: 09/25/25



BOX EAVE / CORNER POST CONNECTION DETAIL FOR HEIGHTS < 14'-0"

S6A SCALE: 3/4" = 1'-0"



CAROUNE SEAL VICENTIAN OP/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864


DATE: 09/25/25

SHEET NO: S6A





CONCRETE BASE RAIL ANCHORAGE



GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318: 3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORS SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEMENT

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- 1. REINFORCEMENT IS BENT COLD.
- 2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- 3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:


 0725-0864


 DATE:
 SHEET NO:

 09/25/25
 \$7

CONCRETE BASE RAIL ANCHORAGE (NO SLAB)

ANCHORAGE BOLT SCHEDULE		
WIND SPEED	BOLT SIZE	
UP TO 115 M.P.H. UP TO 125 M.P.H. UP TO 135 M.P.H. UP TO 145 M.P.H.	1/2" x 6-1/2" Expansion anchor 1/2" x 6-1/2" Expansion anchor 1/2" x 9" Expansion anchor 1/2" x 9" Expansion anchor	





1 S7A

BASE RAIL ANCHORAGE DETAIL (NO SLAB)

SCALE: 3/4" = 1'-0"

GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318:

3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AgaINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCEMENT SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEMENT

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- 1. REINFORCEMENT IS BENT COLD.
- 2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- 3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

VGINEES

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641

828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:

 0725-0864

 DATE:
 SHEET NO:

 09/25/25
 \$7A

CONCRETE BASE RAIL ANCHORAGE (NO LEDGE)



GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318: 3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCE SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCE MENT.

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- 1. REINFORCEMENT IS BENT COLD.
- 2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- 3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:


 0725-0864


 DATE:
 SHEET NO:

 09/25/25
 S7B

CONCRETE BASE RAIL ANCHORAGE (NO LEDGE / NO SLAB)

ANCHORAGE BOLT SCHEDULE		
WIND SPEED	BOLT SIZE	
UP TO 115 M.P.H. UP TO 125 M.P.H. UP TO 135 M.P.H. UP TO 145 M.P.H.	l ' '. '	





GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3.000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318:

3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AgaINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCEMENTS

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- 1. REINFORCEMENT IS BENT COLD.
- 2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- 3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

09/25/2025

INSTALL (1) EXPANSION

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:

 0725-0864

 DATE:
 SHEET NO:

 09/25/25
 \$7C


CONCRETE BASE RAIL ANCHORAGE (CLIP ANGLE ATTACHMENT OPTION)



SCALE: 3/4" = 1'-0"

1 S7D BASE RAIL ANCHORAGE DETAIL (CLIP ANGLE ATTACHMENT OPTION)

SCALE: 3/4" = 1'-0"



JCMT
ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE: 09/25/25

CONCRETE BASE RAIL ANCHORAGE



GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318:

3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCEMENTS. SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEMENTS.

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- 1. REINFORCEMENT IS BENT COLD.
- 2. THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- 3. REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:

 0725-0864

 DATE:
 SHEET NO:

 09/25/25
 \$7E

CONCRETE BASE RAIL ANCHORAGE (NO SLAB)





BASE RAIL ANCHORAGE DETAIL (NO SLAB)

SCALE: 3/4" = 1'-0"

GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318: 3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCE SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEME)

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- REINFORCEMENT IS BENT COLD.
- THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS
- REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.


09/25/2025

PO BOX 27 Pilot Mountain, NC 28641 828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501

DRAWN BY: PROJECT NO: 0725-0864 BKS DATE: SHEET NO: 09/25/25 S7F

CONCRETE BASE RAIL ANCHORAGE (NO LEDGE)



GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318: 3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCE SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEME

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- REINFORCEMENT IS BENT COLD.
- THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR. IS NOT LESS THAN SIX-BAR DIAMETERS.
- REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.


09/25/2025




Aaron Costello 1046 Lipscomb Road Angier NC 27501

DRAWN BY: PROJECT NO: 0725-0864 BKS DATE: SHEET NO: 09/25/25 **S7G**

CONCRETE BASE RAIL ANCHORAGE (NO LEDGE / NO SLAB)





GENERAL NOTES:

ALL CONCRETE MONOLITHIC SLAB DESIGN BASED ON MINIMUM SOIL BEARING CAPACITY OF 1,500 P.S.F.

CONCRETE:

CONCRETE SHALL HAVE A MINIMUM SPECIFIED COMPRESSIVE STRENGTH OF 3,000 P.S.I. AT 28 DAYS.

COVER OVER REINFORCING STEEL:

FOR FOUNDATIONS, MINIMUM CONCRETE COVER OVER REINFORCING BARS SHALL BE PER ACI-318: 3" IN FOUNDATIONS WHERE THE CONCRETE IS CAST AGAINST AND PERMANENTLY IN CONTACT WITH THE EARTH OR EXPOSED TO THE EARTH AND WEATHER AND 1-1/2" ELSEWHERE.

REINFORCING STEEL:

THE TURNDOWN REINFORCING STEEL SHALL BE ASTM A615 GRADE 60. THE SLAB REINFORCE SHALL BE WELDED WIRE FABRIC MEETING ASTM A185 OR FIBERGLASS FIBER REINFORCEME

REINFORCEMENT MAT BE BENT IN THE SHOP OF THE FIELD PROVIDED:

- REINFORCEMENT IS BENT COLD.
- THE DIAMETER OF THE BEND, MEASURED ON THE INSIDE OF THE BAR, IS NOT LESS THAN SIX-BAR DIAMETERS.
- REINFORCEMENT PARTIALLY EMBEDDED IN CONCRETE SHALL NOT BE FIELD BENT.


09/25/2025

PO BOX 27 Pilot Mountain, NC 28641 828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501

DRAWN BY: PROJECT NO: 0725-0864 BKS DATE: SHEET NO: 09/25/25 S7H

SOIL NAIL BASE RAIL ANCHORAGE





BASE RAIL ANCHORAGE DETAIL

SCALE: 3/4" = 1'-0"

HELIX EMBEDMENT INFORMATION:

FOR VERY DENSE OR CEMETED SANDS, COARSE GRAVEL, COBBLES, CALICHE, PRELOADED SILTS AND CLAYS, USE MIN. (2) 4" HELICES WITH MINIMUM 30" EMBEDMENT OR SINGLE 6" HELIX WITH 50" EMBEDMENT — ONE EACH END BASE RAIL AND 20'-0"oc MAX. WITH #4 REBAR AT 5'-0"oc BETWEEN.

FOR CORAL, USE MIN (2) 4" HELICES WITH MINIMUM 30" EMBEDMENT OR SINGLE 6" HELIX WITH 50" EMBEDMENT — ONE EACH END BASE RAIL AND 20'-0"oc MAX. WITH #4 REBAR AT 5'-0"oc BETWEEN.

FOR MED DENSE COARSE SANDS, SANDY GRAVEL, VERY STIFF SILTS, AND CLAYS, USE MIN (2) 4" HELICES WITH MINIMUM 30" EMBEDMENT OR SINGLE 6" HELIX WITH 50" EMBEDMENT — ONE EACH END BASE RAIL AND 20'-0"oc MAX. WITH #4 REBAR AT 5'-0"oc BETWEEN.

FOR LOOSE TO MEDIUM DENSE SANDS, FIRM TO STIFF CLAYS AND SILTS, USE MIN (2) 6" HELICES WITH MINIMUM 50" EMBEDMENT — ONE EACH END BASE RAIL AND 20'-0"oc MAX. WITH #4 REBAR AT 5'-0"oc BETWEEN.

FOR VERY LOOSE TO MEDIUM DENSE SANDS, FIRM TO STIFFER CLAYS AND SILTS AND ALLUVIAL FILL, USE MIN (2) 8" HELICES WITH MINIMUM 60" EMBEDMENT - ONE EACH ED BASE RAIL AND 20'-0"oc MAX. WITH #4 REBAR AT 5'-0"oc BETWEEN.

NOTE:

IN ALL CASES, IF FROST DEPTH EXCEEDS STATED DEPTH, ANCHOR SHOULD EXTEND A MIN. OF 12" BELOW FROST LINE

09/25/2025

JCMT
ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS


PROJECT NO: 0725-0864

DATE: 09/25/25

ASPHALT ANCHOR BASE RAIL ANCHORAGE







JCMT
ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864


DATE: 09/25/25

BOX EVE RAFTER END WALL OPENINGS



TYPICAL BOX EVE RAFTER / END WALL COLUMN FRAME SECTION

NOTE:
ROLL UP DOORS SHALL
HAVE ONE JAMB EACH
SIDE + ONE FRAME
COLUMN BETWEEN OR SITE
SPECIFIC SHALL BE REQ'D.



TYPICAL BOX EVE RAFTER END WALL OPENINGS FRAMING SECTION /25/2025




828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS


PROJECT NO: 0725-0864


DATE: 09/25/25

BOX EVE RAFTER END WALL AND SIDE WALL OPENINGS




TYPICAL END WALL OPENING FRAMING SECTION





POST / BASE RAIL CONNECTION DETAIL

SCALE: 1/2" = 1'-0"



INTERMEDIATE CHORD TO BOTTOM CHORD CONNECTION DETAIL


SCALE: 1/2" = 1'-0"


MIN. 6"x14ga. T.S. COLUMN CONNECTOR SLEEVE SECURE WITH (4) #12-14x3/4" S.D.F. CONNECTOR 3/16 SLEEVE TO BASE RAIL 3/16 (TYP.) T.S. CONTINUOUS BASE RAIL POST / BASE RAIL CONNECTION DETAIL SCALE: 1/2" = 1'-0"

> T.S. TOP CHORD T.S. INTERMEDIATE **CHORD**

INTERMEDIATE CHORD TO TOP CHORD CONNECTION DETAIL

SCALE: 1/2" = 1'-0"






ASSOCIATES, PLLC **PO BOX 27** Pilot Mountain, NC 28641 828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501

DRAWN BY: PROJECT NO: 0725-0864 BKS DATE: SHEET NO: 09/25/25 **S10**




COLUMN OR WINDOW RAIL / WALL GIRT TO POST CONNECTION DETAIL

SCALE: 1/2" = 1'-0"

T.S. COLUMN OR END COLUMN T.S. DOUBLE HEADER / 3/12 3/12 2"x2"x2" 16GA ANGLE CLIP SECURE TO COLUMN AND EITHER TOP OF HEADER OR BOTTOM OF WINDOW RAIL WITH #12-14x3/4" S.D.F.

COLUMN / DOUBLE HEADER CONNECTION DETAIL

SCALE: 1/2" = 1'-0"



DOOR OR WINDOW HEADER RAIL TO POST CONNECTION DETAIL

SCALE: 1/2" = 1'-0"

09/25/2025

ASSOCIATES, PLLC **PO BOX 27**

Pilot Mountain, NC 28641

828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501

DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE:


SHEET NO: 09/25/25 **S11**




END COLUMN / BASE RAIL CONNECTION DETAIL

S12

SCALE: 1/2" = 1'-0"






JCMT
ASSOCIATES, PLLC
PO BOX 27

PO BOX 27 Pilot Mountain, NC 28641 828-310-7160 Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE: 09/25/25




DOUBLE HEADER / COLUMN
CONNECTION DETAIL

SCALE: 1/2" = 1'-0"

S.D.F. (TYP)

- T.S. COLUMN

COLUMN / DOUBLE HEADER
CONNECTION DETAIL
S13 SCALE: 1/2" = 1'-0"



T.S. DOUBLE HEADER

JCMT
ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641

828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501


3/12

 DRAWN BY:
 PROJECT NO:


 0725-0864

 DATE:
 SHEET NO:

 09/25/25
 \$13




COLUMN / LACED HEADER
CONNECTION DETAIL
SCALE: 1/2" = 1'-0"



LACED HEADER / COLUMN CONNECTION DETAIL

S14 SCALE: 1/2" = 1'-0"
CONCRETE BASE RAIL ANCHORAGE



COLUMN / LACED HEADER CONNECTION DETAIL

SCALE: 1/2" = 1'-0"

CAROLLAND SEAL 27874

LAND SEAL 27874

L

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:

 0725-0864

 DATE:
 SHEET NO:

 09/25/25
 \$14

BOX EVE RAFTER LEAN-TO OPTIONS



TYPICAL LEAN-TO OPTIONS FRAMING SECTION (BOTH OPTIONS SHOWN)

MAXIMUM WIDTH OF SINGLE MEMBER ROOF EXTENSION AND LEAN-TO OPTION IS 12'-0" MAXIMUM WIDTH OF DOUBLE MEMBER ROOF EXTENSION AND LEAN-TO IS 15'-0" 12'-0" MAX. LEAN-TO HEIGHT WITH SINGLE COLUMN 16'-0" MAX. LEAN-TO HEIGHT WITH DOUBLE COLUMN



ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE: 09/25/25


LEAN-TO CONNECTION DETAILS



ROOF EXTENSION RAFTER / CORNER POST DETAIL FOR WIDTHS < 12'-0"

1 S15A

SCALE: 3/4" = 1'-0"



ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: PROJECT NO: 0725-0864

DATE: SHEET NO:

S15A

09/25/25

LEAN-TO CONNECTION DETAILS - SINGLE COLUMN



LEAN-TO SINGLE RAFTER / SINGLE COLUMN CONNECTION DETAIL

T.S. DOUBLE RAFTER **VARIES** 2 TO 3 CONNECTOR SLEEVE TO 3/16 воттом 3/16 CHORD (TYP.) SECURE WITH (4) $\#12-14 \times 3/4$ " S.D.F.'S (EACH END) 18ga. U-CHANNEL KNEE ON SINGLE COLUMN BRĂCE FASTENED TO LEAN-TO'S UNDER 8'-0" A RAFTER AND COLUMN 3'-0" BRACE CAN BE USED. ON LEAN-TO'S TALLER THAN 8'-1" A 4'-0" BRACE MUST MIN. 6" LONG, 14ga. CONNEG SLEEVE - SECURE COLUMNO, BE USED. WITH (4) $\#12-14 \times 3/4$ T.S. SINGLE OR DOUBLE COLUMN

LEAN-TO DOUBLE RAFTER / SINGLE COLUMN CONNECTION DETAIL

1A S15B

SCALE: 3/4" = 1'-0"

SCALE: 3/4" = 1'-0"

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641

828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE: 09/25/25


SHEET NO: S15B

LEAN-TO / MAIN FRAME CONNECTION DETAILS



LEAN-TO SINGLE RAFTER / BUILDING FRAME CONNECTION DETAIL

SCALE: 3/4" = 1'-0"



ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS


PROJECT NO: 0725-0864

DATE: 09/25/25

SHEET NO: S15C

VERTICAL ROOF / SIDING OPTION 6" (TYP.) FLASHING -W/ <30'-0" MAXIMUM RAFTER SPAN TYPICAL END ELEVATION - VERTICAL ROOF / SIDING 6" (TYP.) FLASHING LENGTH VARIES DEPENDING ON NUMBER AND SPACING OF RAFTERS TYPICAL SIDE ELEVATION - VERTICAL ROOF / SIDING 09/25/2025 DRAWN BY: PROJECT NO: **Aaron Costello** 0725-0864 BKS 1046 Lipscomb Road **PO BOX 27** SHEET NO: DATE: Angier NC 27501 Pilot Mountain, NC 28641 09/25/25 **S16** 828-310-7160

VERTICAL ROOF / SIDING OPTION



TYPICAL SECTION VERTICAL ROOF / SIDING OPTION

NOTE:

H.S.S. 2-1/2"x2-1/2"x14ga. OR 2-1/4"x2-1/4"x14ga. MATERIAL MAY BE USED FOR TRUSS METAL.



ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641
828-310-7160


Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864


DATE: 09/25/25

SHEET NO: S16A

VERTICAL ROOF / SIDING OPTION



TYPICAL SIDE FRAMING SECTION VERTICAL ROOF / SIDING OPTION




Aaron Costello 1046 Lipscomb Road Angier NC 27501
 DRAWN BY:
 PROJECT NO:

 0725-0864


 DATE:
 SHEET NO:

 09/25/25
 \$16B

SIDE WALL HEADER OPTIONS




HEADER DETAIL FOR DOOR OPENINGS < 4'-0" NTS




HEADER DETAIL FOR DOOR

OPENINGS 4'-1" < TO < 12'-0"
NTS



LACED HEADER DETAIL FOR DOOR OPENINGS 12'-1" < TO < 15'-0" NTS



GENERAL NOTE:

PROVIDE DOUBLE WYTHE ON DOUBLE COLUMNS AND COLUMNS

09/25/2025

ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641


828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS


PROJECT NO: 0725-0864

DATE: 09/25/25

END WALL HEADER OPTIONS




HEADER DETAIL FOR DOOR OPENINGS < 7'-0" NTS



HEADER DETAIL FOR DOOR


OPENINGS 7'-1" < TO < 16'-0"
NTS



LACED HEADER DETAIL FOR DOOR OPENINGS 16'-1" < TO < 20'-0" NTS

GENERAL NOTE:

PROVIDE DOUBLE WYTHE HEADER ON DOUBLE COLUMNS AND LACED COLUMNS



JCMT
ASSOCIATES, PLLC
PO BOX 27
Pilot Mountain, NC 28641

828-310-7160

Aaron Costello 1046 Lipscomb Road Angier NC 27501 DRAWN BY: BKS

PROJECT NO: 0725-0864

DATE: 09/25/25

SHEET NO: S17A