



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

11/14/2025

SUBJECT: **BRES2510-0073**
BUILDING RESIDENTIAL

To: CASTRO AGUILERA ADRIAN

Here are the results of all Inspections located at **135 W STEWART ST:**

Inspection Type: FINAL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: FOOTING
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: OPEN FLOOR
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks:
Notes:

Inspection Type: ROUGH IN
Scheduled Date/Time:
Completed Date/Time:
Inspector: Deen Taylor
Result:
Remarks: eTRAKiT Inspection Request
Notes:



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 11/13/2025
Completed Date/Time: 11/13/2025
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 11/11/2025 11:18 AM Gabriela Cesena

Contact Name: Gabriela Cesena
Site Address: 135 W STEWART ST
Phone: 9105145173
e-Mail: Gabriela.cesenareyes@icloud.com

Owner must be present for inspections. Need footing inspection for porch posts. Unable to verify rafter bearing on ledger at roof line. No porch posts or attachments.