



Permit Reviews

Harnett County

Permit Number: BRES2511-0013

Description: 38' x 15' Monoslope Covered Porch

Applied: 11/6/2025

Approved:

Site Address: 118 WHISPER CREEK CT N

Issued:

Finalized:

City, State Zip Code: LINDEN, NC 28356

Status: RECEIVED

Applicant: 1271 Group

Parent Permit:

Owner: MOSTON MICHAEL J H

Parent Project:

Contractor: 1271 Group

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
11/6/2025	11/6/2025	11/7/2025	CENTRAL PERMITTING INTAKE	CP Bucket	APPROVED	
Notes:						
11/6/2025	11/12/2025	11/12/2025	RESIDENTIAL BUILDING	Brad Sutton	DISAPPROVED	in attachments
Notes: 1. Need rafter size and spacing 2. Need ceiling joist size and spacing 3. Need roof beam size and posts to beam connection method.						
11/12/2025			RESIDENTIAL BUILDING	Building Bucket		
Notes:						