

15-5-37374

HTE# Repair

Harnett County Department of Public Health Improvement Permit

28702

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Boone Trail Emergency Services PROPERTY LOCATION: 7016 US 421 N
 NEW ☐ REPAIR ☒ EXPANSION ☐ SUBDIVISION _____ LOT # _____
 Type of Structure: Existing Building Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 215 GPD
 Number of bedrooms: _____ Number of Occupants: _____ max
 Basement ☐ Yes ☒ No
 Pump Required: ☒ Yes ☐ No ☐ May be required based on final location and elevations of facilities
 Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well _____ feet Permit valid for: 30 days ☐ Five years
 Permit conditions: _____ ☐ No expiration

Authorized State Agent: Bryan McSwain, PEHS Date: 1/5/2016 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Boone Trail Emergency Services PROPERTY LOCATION: 7016 US 421 N
 Facility Type: Existing Building ☐ New ☐ Expansion ☒ Repair
 Basement? ☐ Yes ☐ No Basement Fixtures? ☐ Yes ☐ No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 215 GPD
 (See note below, if applicable ☐ 25% Reduction System (Repair)
 Installation Requirements/Conditions
 Septic Tank Size Existing gallons
 Pump Tank Size Existing gallons
 Number of trenches 4
 Exact length of each trench 50 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 24 inches
 (Trench bottoms shall be level to $\pm 1/4"$
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM
 Conditions: Septic Contractor to meet on site prior to installing system
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed
 36" above the trench bottom)
 Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McSwain, PEHS Date: 1/5/2016
 Construction Authorization Expiration Date: 2/5/2016

✓ 15-5-37374

HTE# Repair

Permit # 28702

Harnett County Department of Public Health
Site Sketch

ISSUED TO: Boone Trail Emergency Services PROPERTY LOCATOR: 7016 US 421 N SUBDIVISION _____ LOT # _____

Authorized State Agent: [Signature] Date: 1/5/2015

