

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Add/Alter

Name: _____

Address: 35 Plantation Dr.

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 4/19/18

Building Official: [Signature]

ADDRESS : 35 PLANTATION DR SUBDIV:
 CONTRACTOR : SAMCO GENERAL CONTRACTORS PHONE : (336) 985-5430
 OWNER : HUFF AND PENNINK HOLDINGS LLC PHONE : (910) 221-7509
 PARCEL : 09-9565-01- -0282- -97-
 APPL NUMBER: 17-50042562 CP COMMERCIAL ADD & ALTER
 DIRECTIONS : T/S: 10/16/2017 04:07 PM DJOHNSON --
 35 PLANTATION DR
 ORTHODONTIST IS WANTING TO EXPAND INTO
 THE EMPTY UNIT BESIDE HER EXISTING
 BUSINESS

STRUCTURE: 000 000 EXPANDING EXISTING BUSINESS TO NEXT UNIT

FLOOD ZONE : FLOOD ZONE X
 PROPOSED USE : EXPANSION SEPTIC - EXISTING? : SEWER

PERMIT: CBCO 00 CP BUILDING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
C153 01	2/14/18 2/14/18	TSG AE	C*BLDG ROUGH IN TIME: 17:00 VRU #: 003088952 T/S: 02/13/2018 12:49 PM LLUCAS ----- T/S: 02/13/2018 02:12 PM BPETRICH ----- this is for interior wall upfit. told contractor his next inspection is for above ceiling
C169 01	4/02/18 4/02/18	TSG AP	C*OVERHEAD ELE, MECH, PLB TIME: 17:00 VRU #: 003108768 T/S: 03/29/2018 02:02 PM BPETRICH ----- LOCK BOX CODE IS 2494 - KEY WILL GET YOU IN THE MAIN BUILDING AND IN SUITE 204
C179 01	4/13/18 4/13/18	TSG DA	C*BLDG FINAL TIME: 17:00 VRU #: 003113982 T/S: 04/12/2018 11:28 AM JBROCK ----- lock box code - 2494 1- verify use of tamper resistant receptacles and locations with eng. 2-verify/label all gfi receptacles 3-install clean out cover on wall clean out 4-provide placard for arcfault current per eng design 13673. 5-check lift pump leaking drain.
F854 01	4/13/18 4/12/18	RKD AP	FM*FINAL INSPECTION TIME: 17:00 VRU #: 003113941
C179 02	4/19/18	TI	C*BLDG FINAL TIME: 17:00 VRU #: 003116274 T/S: 04/18/2018 01:25 PM BPETRICH -----

PERMIT: CPEC 00 CP ELECTRICAL COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E251 01	2/14/18 2/14/18	TSG AE	C*ELEC ROUGH IN TIME: 17:00 VRU #: 003088960 T/S: 02/13/2018 12:49 PM LLUCAS ----- T/S: 02/13/2018 02:12 PM BPETRICH ----- this is for interior wall upfit. told contractor his next inspection is for above ceiling
E265 01	4/13/18 4/13/18	TSG DA	C*ELEC FINAL TIME: 17:00 VRU #: 003114006 T/S: 04/12/2018 11:28 AM JBROCK ----- 1- verify use of tamper resistant receptacles and locations with eng. 2-verify/label all gfi receptacles 3-install clean out cover on wall clean out 4-provide placard for arcfault current per eng design 13673.

ADDRESS : 35 PLANTATION DR
CONTRACTOR : SAMCO GENERAL CONTRACTORS
OWNER : HUFF AND PENNINK HOLDINGS LLC
PARCEL : 09-9565-01- -0282- -97-
APPL NUMBER: 17-50042562 CP COMMERCIAL ADD & ALTER

SUBDIV:
PHONE : (336) 985-5430
PHONE : (910) 221-7509

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E265 02	4/19/18	TI	5-check lift pump leaking drain. C*ELEC FINAL TIME: 17:00 VRU #: 003116282 T/S: 04/18/2018 01:25 PM BPETRICH

PERMIT: CPPC 00 CP PLUMBING COMMERCIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P351 01	2/14/18 2/14/18	TSG AE	C*PLUMB ROUGH IN TIME: 17:00 VRU #: 003088978 T/S: 02/13/2018 12:49 PM LLUCAS T/S: 02/13/2018 02:12 PM BPETRICH this is for interior wall upfit. told contractor his next inspection is for above ceiling
P361 01	4/13/18 4/13/18	TSG DA	C*PLUMB FINAL TIME: 17:00 VRU #: 003114014 T/S: 04/12/2018 11:28 AM JBROCK 1- verify use of tamper resistant receptacles and locations with eng. 2-verify/label all gfi receptacles 3-install clean out cover on wall clean out 4-provide placard for arcfault current per eng design 13673. 5-check lift pump leaking drain.
P361 02	4/19/18	TI	C*PLUMB FINAL TIME: 17:00 VRU #: 003116290 T/S: 04/18/2018 01:25 PM BPETRICH

COMMENTS AND NOTES