

HTE #: 18-5-42687

HARNETT COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH  
307 CORNELIUS HARNETT BOULEVARD  
LILLINGTON, NC 27546

**EXISTING SEPTIC SYSTEM INSPECTION**

Name: J&M GSO FV, LLC Phone #: 919.577.0746

Address: 4792 Rawls Church Rd. Fuquay-Varina, NC 27526

Name of Mobile Home Park or S/D: NA

Name of Owner (if different): Same

Address of Owner (if different): Same

Property Location (State Road name and #): 4792 Rawls Church Rd. (SR 1415)

Purpose of Inspection: Addition - Warehouse Storage (40'x125'). Proposed addition not within septic area. Front septic w/ sanitary tee intact not within vicinity of addition.

**The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If the system should malfunction, the owner is responsible for any necessary repairs.**

**THIS INSPECTION IS VOID IF:**

1. the intended use of the septic system should change, and/or
2. the system should fail or malfunction, and/or
3. the owner or tenant of the property change, and/or
4. after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM  
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

  
\_\_\_\_\_  
Signature of Environmental Health Specialist

02/20/2018  
\_\_\_\_\_  
Date