



Harnett
C O U N T Y
NORTH CAROLINA

Pre-Development Info Sheet

18.5.43059

Harnett County, North Carolina
Planning Department

108 E. Front Street/P.O. Box 65, Lillington, NC 27546
Phone: (910) 893-7525; opt. 4/Fax: (910) 814-6459

Date of Meeting 2.6.18 @ 10:30A

9AM

18.5.43059

*cont. agenda
9AM RAG
2.5.18 @ 2:45P*

Development Name:

Development Type:

- Major Subdivision Preliminary Plan/Plat Commercial Site Plan
 Major Subdivision Final Plan/Plat Multi-Family Site Plan

Applicant Information

Owner of Record:

Name: Judy Vena
 Address: _____
 City/State/Zip: _____
 E-mail: _____
 Phone: _____
 Fax: _____
 Mobile: 919 770 6208

Developer/Engineer/Surveyor:

Name: _____
 Address: _____
 City/State/Zip: _____
 E-mail: _____
 Phone: _____
 Fax: _____
 Mobile: _____

Property Description

PIN(s): 9505-30 0468 Address: Hullum Grove Rd Acreage: 5.24 Lots: 1
CA 9504-0089-02

Project Description:

36x10x 8 bay carport
existing unpermitted business on prop.

Specific Departments needed/ requested to attend:

- Building Inspections - (910)893-7525, x3
 E911/ Addressing - (910)814-2038
 Engineering - (910)893-7555
 Environmental Health - (910)893-747 alvee
 Fire Marshall - (910)893-7580 Rodney
 Planning - (910)893-7525, x4 Landm
 Public Utilities Department - (910)893-7575

*RA20R
 County water
 existing septic*

Global Location Inquiry - Building Permit Applications

Property address : 1507 HILLMON GROVE RD
PARCEL NUMBER : 09-9564- - -0089- -02-

09

Type options, press Enter.

2=Application inq 3=Structure inq 4=Permit inq 5=Inspection inq

Opt	Appl Nbr	Type	Stat	Date	Tenant Nbr/Name
-	18 50043059	CDGC	PP	1/09/18	Calport
-	10 50025418	CPTS	CO	10/20/10	200AMP-xmas lights
-	08 50020792	CPTS	CO	8/21/08	elect-area light
-	00 50000241	CMFH	CL	9/22/00	SMH-storage
-	00 40000305	HCPE	PP	3/29/00?	
-	00 40000304	HCPE	CO	3/29/00?	
-	00 30001304	MFHM	PP	7/11/00	mh storage(permitted)
-	00 30000897	MFHM	PP	5/16/00	

F3=Exit F12=Cancel

Lindm

Conditional use
personal serv. est.

added an addition
in front of bldg.

word bldg - no permits

Oliver

porta john
doesn't need anything

Rodney

↑ 10,000 sq. ft.

need measurements

sprinklered unless fire separated

fire hydrant needed

6" water main

Shane

uncovered brick flow

All



HUNTON GROVE RD

110

31

31

6

1385

1387

1431

1465

1507

1531

1545

