

MCE

June 7, 2019

Re: YMCA of Harnett County

Addenda Items:

Electrical

Replace all fixtures noted in fixture schedule as existing with new equivalent lumen LED fixtures.

Existing 480/277 volt lighting panel "A" can remain in place as the wall will not be removed.

Sincerely,

McDowell Consulting Engineers, Inc.

Gregory L. McDowell, PE

