



Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550  
fax: 910-893-9429

June 2, 2005

Scottie VanHook  
P O Box 655  
Lillington, NC 27546

*Conf# - 30589  
disapproved  
6/3*

RE: Harnett County Land Use Application - HTE# 05-5-12196

Mr. Vanhook,

The Harnett County Department of Public Health, Environmental Health Division on June 1, 2005, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a 41 x 35 addition to an existing home, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

    **15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.**

**Your options are:**

**Option A – Reduce size of addition so that the addition is 5' from all parts of septic system.**

**Option B - At Central Permitting, you can apply for a new soil evaluation for your property and possibly replace existing septic system with a new one.**

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

*Joe West, R.S. sgs*

Joe West, R. S.  
Environmental Health Specialist  
Harnett County Department of Public Health

JW/sgs