

HTE # 05-50012196R

17649

OPERATIONS PERMIT

Name: (owner) Scottie Van Hook New Installation Septic Tank Repair

Property Location: SR# 1115 Nitrification Line Expansion

Subdivision Crestview Lot # 77 Tax ID # _____ Quadrant # _____

Contractor: C9C Backhoe Registration # _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other Pump to Tin chips

Size of tank: Septic Tank: 1000 gallons Pump Tank: existing gallons
1000 gallon pump tank

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 200 ft. width of ditches 3 ft. depth of ditches 18.24 in.

French Drain Required: _____ Linear feet Date: 7-6-05

PERMIT NO. 22103 Inspected by: Joe WARS

