

HARNETT COUNTY HEALTH DEPARTMENT

HTE# 05-500 12793R

NO AUTHORIZATION TO CONSTRUCT. To Be Issued until I meet Ins. Talker onsite

05-5-12792

IMPROVEMENT PERMIT

22735

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Scott Kramer New Installation Septic Tank Repair

Property Location: SR# 1115 Nitrification Line Expansion

Subdivision Crestview Lot # 182

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: existing 3 Bedroom Lot Size: .70Ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: _____ ft. This is for correcting drain field pool conflict of 15' separation but You CAN NOT Add ANY Bedrooms To

Following is the minimum specifications for sewage disposal system on above captioned property. Home Subject to final approval.

Type of system: Conventional Other Chamber - Infiltrator Quick 4

Size of tank: Septic Tank: existing gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches _____ ft. exact length of each ditch _____ ft. width of ditches _____ ft. depth of ditches _____ in.

French Drain Required: _____ Linear feet

Date: 08-25-05


This permit is subject to revocation if site plans or intended use change. PERMIT EXPIRES 5 YEARS FROM ABOVE DATE

Signed: [Signature] Environmental Health Specialist

Muit meet Installer onsite for Final Layout.

Suggest you get original Installer to do Repair

MUIT REMOVE Drain Lines from the 15' AREA Around Pool - MUIT Replace existing Infiltrator Quick 4 Panels UNTIL 300' of Drain Field exists - Area useable is from



No More Bedrooms CAN Be Added To This Home