



May 25, 2007

Tammy Jackson
P O Box 3182
Buies Creek, NC 27506

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7550
fax: 910-893-9429

RE: Harnett County Land Use Application # 06-5-15523R

Dear Mrs. Jackson,

The Harnett County Department of Public Health, Environmental Health Division on May 23, 2007 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a 4th bedroom, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

**15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.
(Permits are for a 3 bedroom.)**

Your options are:

- #1 - Remove closet from one room and therefore it would not be considered a bedroom. (This is the easiest option)*
- #2 - Apply for a soil evaluation for adding line to existing system and repair area for 4th bedroom. Where the system is currently located, line addition is not going to be easily done.*

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/sgs