



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

4/14/2023

**SUBJECT: CARE07-50016618  
BUILDING RESIDENTIAL**

To:

Here are the results of all Inspections located at **2678 SHERIFF JOHNSON RD:**

Inspection Type: ENVIR. HLTH. CONFIRMATION  
Scheduled Date/Time: 2/8/2007  
Completed Date/Time: 2/2/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: BLDG PLAN REVIEW  
Scheduled Date/Time: 2/16/2007  
Completed Date/Time: 2/16/2007  
Inspector: Unassigned  
Result: DISAPPROVED  
Remarks:  
Notes:

Inspection Type: BLDG PLAN REVIEW  
Scheduled Date/Time: 2/23/2007  
Completed Date/Time: 2/23/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: R BLDG FOOTING / TEMP SVC POLE  
Scheduled Date/Time: 3/1/2007  
Completed Date/Time: 3/1/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: R BLDG FOUND & TEMP SVC POLE  
Scheduled Date/Time: 3/9/2007  
Completed Date/Time: 3/9/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: Please put me on the schedule for mid afternoon. Thanks.

Inspection Type: R OPEN FLOOR  
Scheduled Date/Time: 3/13/2007  
Completed Date/Time: 3/13/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FOUR TRADE ROUGH IN  
Scheduled Date/Time: 6/20/2007  
Completed Date/Time: 6/20/2007  
Inspector: Unassigned  
Result: DISAPPROVED  
Remarks:  
Notes: 1-WIRING NOT MADE UP. SHALL BE STRIPPED WITH GROUNDS MADE UP. 2-NO SMOKE DECTORS WIRED. 3-CANNOT USE A 20 AMP CIRCUIT TO FEED A 15 AMP RATED WIRE. 4-CANNOT HAVE A JUNCTION BOX IN CEILING THAT IS NONACCESSABLE. 5-WATERLINES, TUB AND DRAIN LINES NOT TESTED. 6-LAVATORY TRAY CANNOT BE BELOW FLOOR. 7-LAVATORY VENT WRONG. NEED TO GO UP IN WALL OR USE AIR ADMITTANCE VALVE. 8-TOILET FLANGE SHALL BE ANCHORED WITH CORRISION RESISTANT SCREWS. 9-ALL PENETRATIONS THROUGH TOP AND BOTTOM PLATE SHALL BE FIR FIRE CAULKED. KEN SLATTUM

Inspection Type: ONE TRADE ROUGH IN  
Scheduled Date/Time: 6/20/2007  
Completed Date/Time: 6/19/2007  
Inspector: Unassigned  
Result: CANCELLED  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ONE TRADE ROUGH IN

Scheduled Date/Time: 6/20/2007

Completed Date/Time: 6/19/2007

Inspector: Unassigned

Result: CANCELLED

Remarks:

Notes:

Inspection Type: ONE TRADE ROUGH IN

Scheduled Date/Time: 6/25/2007

Completed Date/Time: 6/25/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: R INSULATION INSPECTION

Scheduled Date/Time: 7/9/2007

Completed Date/Time: 7/9/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: ONE TRADE FINAL

Scheduled Date/Time: 9/18/2007

Completed Date/Time: 9/18/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes: