



Harnett County Government Complex  
307 Cornelius Harnett Boulevard  
Lillington, NC 27546

ph: 910-893-7550

fax: 910-893-9429

April 20, 2007

John E. Lowe  
7359 Van Grayson Ln.  
Fayetteville, NC 28314

**RE: Existing Tank Application 07-5-17295**

Dear Mr. Lowe,

The Harnett County Department of Public Health, Environmental Health Division on April 19, 2007 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting an addition to your home totaling 5 bedrooms, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

**The permit issued for this home was for a 3 bedroom home. (See attached copies) Your option is to pay for a soil evaluation to see if there are enough suitable soils so that enough line is added to existing drain field for a 5 bedroom home. The 1000 gallon tank will be too small for 5 bedrooms and would have to be replaced with a 1500 gallon tank, if there is enough area for septic system and required repair area for a 5 bedroom home.**

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

*Joe West, R.S.*  
Joe West, R. S.

Environmental Health Specialist  
Harnett County Department of Public Health