

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: Occupancy: _____

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3 - Pool

Name: Schumacher

Address: 479 DL Phillips Ln.

Date: 3.20.12

Building Official: J. Michael Reavis

Permit Numbers

Building: 07-50017471

Electrical: 11

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

PREPARED 3/19/12, 14:02:21
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 3/20/12

ADDRESS . . : 479 D L PHILLIPS LN
CONTRACTOR :
OWNER . . . : SCHUMACHER JAMES THOMAS &
PARCEL . . . : 03-9596- - -0038- -01-
APPL NUMBER: 07-50017471 CP ADD & ALTER RESIDENTIAL

SUBDIV:
PHONE :
PHONE :

DIRECTIONS : TAKE 27 WEST PAST WHHS ACOUPLE OF MILES
TAKE TINGEN RD ON LEFT TINGEN RD HAS A
DEAD END DL PHILLIPS LANE ON LEFT JB

APPL NOTES : BPMN 1/04/07 CUSTOMER WANTED TO PULL PERMITS AS
OWNER BUT THEN CONTRACTOR SAID HIRING
SUBS SO NEEDS TO GET SUBS ON APP BEFORE
PURCHASING TRADE PERMITS. JDAVIS

STRUCTURE: 000 000 11X17 SLAB FOR JACUZZI (FUTURE SR & BR)
FLOOD ZONE : FLOOD ZONE X
PROPOSED USE : SLAB/JACUZZI SEPTIC - EXISTING? : EXS
WATERSHED DISTRICT : NA

PERMIT: CPBP 00 CP BUILDING PERMIT

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------|--------------------|--|
| R229 01 | 3/05/12 3/05/12 | MR DA | TWO TRADE FINAL TIME: 17:00 VRU #: 002199388 T/S: 03/05/2012 12:52 PM MREARIC rec'd engineers letter on structure, still need wiring to comply with NEC for pools |
| R229 02 | 3/20/12 <u>3.20.12</u> | TI <u>AP.MR</u> | TWO TRADE FINAL TIME: 17:00 VRU #: 002204840 |

COMMENTS AND NOTES

