

PREPARED 8/16/07, 14:00:58
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 50
DATE 8/17/07

ADDRESS . : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : LASATER WILLIAM G JR PHONE :
PARCEL . . : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07 <u>8-17</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982 <u>K5</u> ----- COMMENTS AND NOTES -----

PREPARED 8/24/07, 14:37:41
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 63
DATE 8/27/07

ADDRESS . : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . : LASATER WILLIAM G JR PHONE :
PARCEL . : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD

FLOOD ZONE : FLOOD ZONE X

PROPOSED USE : ADDITION

SEPTIC - EXISTING? : YES

PERMIT: CPBP 00 CP BUILDING PERMIT

	REQUESTED	INSP	DESCRIPTION
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	8/17/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982
	8/17/07	AP	
B103 01	8/27/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474808

8-27

AP

KS

----- COMMENTS AND NOTES -----

PREPARED 8/30/07, 14:22:58
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 33
DATE 8/31/07

ADDRESS : 2070 OLD STAGE RD S
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE
OWNER : LASATER WILLIAM G JR
PARCEL : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

SUBDIV:
PHONE : (919) 894-5591
PHONE :

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD

FLOOD ZONE : FLOOD ZONE X

PROPOSED USE : ADDITION

SEPTIC - EXISTING? : YES

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982
	8/17/07	AP	
B103 01	8/27/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474808
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B105 01	8/29/07	TI	R*OPEN FLOOR VRU #: 001476021
	8/28/07	CA	
B105 02	8/31/07	TI	R*OPEN FLOOR VRU #: 001478346

8-31

AP

KS

COMMENTS AND NOTES

PREPARED 10/01/07, 14:01:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 35
DATE 10/02/07

ADDRESS . : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : LASATER WILLIAM G JR PHONE :
PARCEL . . : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982
	8/17/07	AP	
B103 01	8/27/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474808
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B105 01	8/29/07	TI	R*OPEN FLOOR VRU #: 001476021
	8/28/07	CA	
B105 02	8/31/07	KS	R*OPEN FLOOR VRU #: 001478346
	8/31/07	AP	
R425 01	10/01/07	TI	FOUR TRADE ROUGH IN VRU #: 001496385
	10/01/07	CA	
R425 02	10/02/07	TI	FOUR TRADE ROUGH IN VRU #: 001496637

10-2

DA

----- COMMENTS AND NOTES -----

Violation Notice
Do Not Remove

Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-4876 Fax (910) 893-2793

07-50018173

1. T1 and T1A trusses shall have hurricane tie on screened porch end as well as the exterior wall end.
2. Washing machine stand pipe shall be minimum of 34 inches. Currently at 31 inches.
3. Window (bottom sash) to the left of door shall be tempered. (Knob side)

Ok to side and insulate.
Code Enforcement Official

Signature ____ Ken Slattum ____ 910-984-4766 _____

ADDRESS : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : LASATER WILLIAM G JR PHONE :
PARCEL : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982
	8/17/07	AP	
B103 01	8/27/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474808
	8/27/07	AP	1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B105 01	8/29/07	TI	R*OPEN FLOOR VRU #: 001476021
	8/28/07	CA	
B105 02	8/31/07	KS	R*OPEN FLOOR VRU #: 001478346
	8/31/07	AP	
R425 01	10/01/07	TI	FOUR TRADE ROUGH IN VRU #: 001496385
	10/01/07	CA	
R425 02	10/02/07	KS	FOUR TRADE ROUGH IN VRU #: 001496637
	10/02/07	DA	1. Truss T1 and T1A shall have hurricane ties on screen porch wall. 2. Washing machine stand pipe shall be 34 inches or higher. 3. Wind shall be tempered to left side of door when looking out from inside. Ok to side and insulate
R425 03	10/10/07 10-10	TI AP	FOUR TRADE ROUGH IN VRU #: 001501915

PERMIT: CPPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	10/10/07 10-10	TI AP	R*INSULATION INSPECTION VRU #: 001501923

COMMENTS AND NOTES

PREPARED 11/06/07, 14:03:17
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 29
DATE 11/07/07

ADDRESS : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : LASATER WILLIAM G JR PHONE :
PARCEL : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

	REQUESTED	INSP	DESCRIPTION
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS
E217 01	11/07/07	TI	R*ELEC RECONNECT VRU #: 001516970
	<u>11/07</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Type of Construction: Elect. Recon

Owner of Building: 2070 Old Stage

Building Address: _____

Zoning District: _____

Zoning Permit No.: _____

Conditional Use Permit No.: _____

Building Permit No.: _____

Electrical Permit No.: 07-5-18173

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 11-7-07
Ken [Signature]

Building Official

Zoning Official

PREPARED 2/19/08, 14:05:09
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 4
DATE 2/20/08

ADDRESS : 2070 OLD STAGE RD S SUBDIV:
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER : LASATER WILLIAM G JR PHONE :
PARCEL : 07-0588- - -0088- - -
APPL NUMBER: 07-50018173 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 421 SOUTH TO HARNETT CO AIRPORT TURN
RIGHT ON OLD STAGE RD SOUTH AND GO TO 2
MILES AND HOUSE IS ON RIGHT. GRAY
HOUSE WITH PORCH ACROSS FRONT.
T/S: 08/06/2007 12:12 PM DJOHNSON --

STRUCTURE: 000 000 40X24 FAMILY ROOM AND UTILITY ROOM ADD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/07 8/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001468982
B103 01	8/27/07 8/27/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001474808 1. Fire block at floor wall intersection on rear of garage wall. Stud bay cannot be open to floor system. 2. Plywood inside of garage wing walls 3. Nail hurricane ties on front of living room wall. 4. All wire and plubing passing thru top and bottom plate shall be fire caulked. 5. Install fire place Do not insulate.
B105 01	8/29/07 8/28/07	TI CA	R*OPEN FLOOR VRU #: 001476021
B105 02	8/31/07 8/31/07	KS AP	R*OPEN FLOOR VRU #: 001478346
R425 01	10/01/07 10/01/07	TI CA	FOUR TRADE ROUGH IN VRU #: 001496385
R425 02	10/02/07 10/02/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001496637 1. Truss T1 and T1A shall have hurricane ties on screen porch wall. 2. Washing machine stand pipe shall be 34 inches or higher. 3. Wind shall be tempered to left side of door when looking out from inside. Ok to side and insulate
R425 03	10/10/07 10/10/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001501915
R429 01	2/20/08 <u>2-20</u>	TI <u>AT</u>	FOUR TRADE FINAL VRU #: 001565860

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>Residential</u>	Conditional Use Permit No.: _____
Type of Construction: <u>V-Addition</u>	Building Permit No.: _____
Owner of Building: <u>William Kester</u>	Electrical Permit No.: _____
Building Address: <u>2070 Old Stage S</u>	Insulation Permit No.: _____
Zoning District: <u>V</u>	Plumbing Permit No.: _____
Zoning Permit No.: _____	Mech. Permit No.: _____
Date: <u>2-20-08</u>	Envir. C.O. No.: _____
<u>Km Slatten</u>	
Building Official	Zoning Official