

www.harnett.org

August 22, 2007

Ed Ray 216 Hawkins Ave. Sanford, NC 27330 Harnett County Government Complex 307 Cornelius Harnett Boulevard Lillington, NC 27546

> ph: 910-893-7550 fax: 910-893-9429

RE: Harnett County Land Use Application # 07-5-18251

Dear Mr. Ray,

The Harnett County Department of Public Health, Environmental Health Division on August 21, 2007 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting a home addition, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is *UNSUITABLE* for the addition requested. Therefore, your request for an existing tank is *DENIED*. The site is denied based on the following:

	15A NCAC 18A.1950 a(16)	Any swimming poo	l must be 15' fron	any part of septic system.
--	-------------------------	------------------	--------------------	----------------------------

X 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.

__X_ 15A NCAC 18A.1950 (10) - Any building to be 5' from drain line. (Can not drive or park on septic system)

Your proposed addition to the home would be on top of your existing septic system. We cannot allow you to build on top of your septic system or repair area. You can not drive or park on top of septic system either. Your options are:

#1 - Change the addition to the home so that the addition is not being built on top of drain field or being driven on.

#2 - Apply for a new soil evaluation to see if the septic system and repair area may be relocated to accommodate the addition.

If you should have any questions or concerns, I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely.

Joe West, R. S.

Environmental Health Specialist

Harnett County Department of Public Health