



December 21, 2007

Donald Kane, Jr.
135 Holly Oak Circle
Bunnlevel, NC 28323

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

Re: Existing Tank Application # 07-5-19042

Dear Mr. Kane,

The Harnett County Department of Public Health, Environmental Health Division on December 19, 2007, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting an addition with a 4th bedroom, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area. (Lot was permitted for 3 bedrooms)
- 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

Your options are:

- #1 - Fill out soil evaluation application at Central Permitting to see if there is enough space to add line and repair for 4th bedroom.
- #2 - Add the room without a closet and not use as a bedroom.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

Joe West, R.S.
Joe West, R.S.

Environmental Health Specialist
Harnett County Department of Public Health

Donald Kane Sr
135 Holly Oak Circle
Bunnlevel NC 28323


The Harnett County Department of Public Health, Environmental Health Division on ~~12-19-20~~ 1/5/21 evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting Addition of 4th Bedroom, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

- _____ 15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.
- 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area. lot was permit for 3 Bedroom
- _____ 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,



Environmental Health Specialist
Harnett County Department of Public Health

Your Options Are

#1 - Fill out Soil Eval at CP to see if there is space enough to add Line & Repair for 4th Bedroom.

#2. ~~Re-do~~ Add ^{the} room without closet & not use ASABed room.