

PREPARED 7/30/08, 14:01:32
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 59
DATE 7/31/08

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

	REQUESTED	INSP	DESCRIPTION	
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS	
B101 01	<u>7/31/08</u> <u>7-31-08</u>	TI <u>ARBS</u>	R*BLDG FOOTING / TEMP SVC POLE	VRU #: 001652045

----- COMMENTS AND NOTES -----

ADDRESS : 154 MELS MEADOWS DR

SUBDIV:

CONTRACTOR :

PHONE :

OWNER : HICKS RONALD WAYNE

PHONE :

PARCEL : 05-0645- - -0022- -11-

APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL

DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON

MELS MEADOWS DR LOT 43 JB

LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL

FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
	7/31/08	AP	
B103 01	8/06/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677

AP. MR

COMMENTS AND NOTES

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08 7/31/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
B103 01	8/06/08 8/06/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677
B105 01	8/18/08 <u>8.18.08</u>	TI <u>APBS</u>	R*OPEN FLOOR VRU #: 001663566

----- COMMENTS AND NOTES -----

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBRD W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08 7/31/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
B103 01	8/06/08 8/06/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677
B105 01	8/18/08 8/18/08	BS AP	R*OPEN FLOOR VRU #: 001663566
R425 01	8/25/08 <i>8-25-08</i>	TI <i>DAB</i>	FOUR TRADE ROUGH IN VRU #: 001667252

----- COMMENTS AND NOTES -----

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
	7/31/08	AP	
B103 01	8/06/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677
	8/06/08	AP	
B105 01	8/18/08	BS	R*OPEN FLOOR VRU #: 001663566
	8/18/08	AP	
R425 01	8/25/08	BS	FOUR TRADE ROUGH IN VRU #: 001667252
	8/25/08	DA	Must have all holes in top and bottom plate firecaulked before insulation inspection. call to reschedule. All other trades ok.
R425 02	8/27/08	TI	FOUR TRADE ROUGH IN VRU #: 001668235
	<u>8/27/08</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

PREPARED 8/28/08, 14:00:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 8/29/08

ADDRESS . . : 154 MELS MEADOWS DR
CONTRACTOR :
OWNER . . : HICKS RONALD WAYNE
PARCEL . . : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	8/29/08 <u>8-29-08</u>	TI <u>APBS</u>	R*INSULATION INSPECTION VRU #: 001669605

----- COMMENTS AND NOTES -----

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBDR W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : .00 SEPTIC - EXISTING? : NEW

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08 7/31/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
B103 01	8/06/08 8/06/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677
B105 01	8/18/08 8/18/08	BS AP	R*OPEN FLOOR VRU #: 001663566
R425 01	8/25/08 8/25/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001667252 Must have all holes in top and bottom plate firecaulked before insulation inspection. call to reschedule. All other trades ok.
R425 02	8/27/08 8/27/08	BS AP	FOUR TRADE ROUGH IN VRU #: 001668235
R429 01	10/13/08 <i>10-13-08</i>	TI <i>DABS</i>	FOUR TRADE FINAL VRU #: 001690668

----- COMMENTS AND NOTES -----

ADDRESS : 154 MELS MEADOWS DR SUBDIV:
CONTRACTOR : PHONE :
OWNER : HICKS RONALD WAYNE PHONE :
PARCEL : 05-0645- - -0022- -11-
APPL NUMBER: 08-50020145 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : 401 N LEFT CHRISTIAN LIGHT RD LEFT ON
MELS MEADOWS DR LOT 43 JB
LAND NOTES : LXMN 6/04/03 LOT 43

STRUCTURE: 000 000 32X30 ADDITION MBRD W/BATH FUTURE POOL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : .00 SEPTIC - EXISTING? : NEW

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/31/08 7/31/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001652045
B103 01	8/06/08 8/06/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001656677
B105 01	8/18/08 8/18/08	BS AP	R*OPEN FLOOR VRU #: 001663566
R425 01	8/25/08 8/25/08	BS DA	FOUR TRADE ROUGH IN VRU #: 001667252 Must have all holes in top and bottom plate firecaulked before insulation inspection. call to reschedule. All other trades ok.
R425 02	8/27/08 8/27/08	BS AP	FOUR TRADE ROUGH IN VRU #: 001668235
R429 01	10/13/08 10/13/08	BS DA	FOUR TRADE FINAL VRU #: 001690668 need plastic under addition min 6mil lapped joints 12 inches.
R429 02	10/22/08 <u>10-22-08</u>	TI <u>APBS</u>	FOUR TRADE FINAL VRU #: 001695600

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD Addition

Owner: Kenneth Wayne Hicks

911 Address: 154 Mel's Meadows

PV

State: NC Zip Code: 27526

Date: 10-22-08

Brad Ginter

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: _____

08-5-2014