

HTE# 08-5-21203

# Harnett County Department of Public Health

25115

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Tom + Marilyn D'OSTROPH / AWD PROPERTY LOCATION:  Hwy 55  
 NEW  REPAIR  EXPANSION  SUBDIVISION WILDWOODS LOT # \_\_\_\_\_  
 Type of Structure: Ex SFD Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_  
 Proposed Wastewater System Type: 25% REDUCTION System  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years  
 Permit conditions: \_\_\_\_\_  No expiration

Authorized State Agent: James E. Markham Date: 11-19-08 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Tom + Marilyn D'OSTROPH / AWD PROPERTY LOCATION: Hwy 55  
 Facility Type: Ex SFD  New  Expansion  Repair SUBDIVISION Wildwoods LOT # \_\_\_\_\_  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* 25% REDUCTION System (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable   
25% REDUCTION System (Repair)  
 Installation Requirements/Conditions  
 Septic Tank Size Ex 1000 gallons Number of trenches 1  
 Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 90 feet Trench Spacing: 9 Feet on Center  
 Trenches shall be installed on contour at a Soil Cover: 6 inches  
 Maximum Trench Depth of: 20-26" max inches (Maximum soil cover shall not exceed  
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)  
 in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe  
 Conditions: \_\_\_\_\_ 2 inches above pipe  
12 inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 11-19-08  
 Construction Authorization Expiration Date: 11-19-13

HTE# 08-5-21203

Permit # 25115

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Tom + Marilyn D'ASTROPH SUBDIVISION Wild Winds LOT #         

Authorized State Agent: James E. Marshant Date: 11-19-08

\* DO NOT  
DRIVE OVER  
PAVE ON  
DISTURB  
EXISTING SYSTEM  
AREA OR  
ADDITIONAL  
LINE.

1ST LINE  
TO BE  
ABANDONED

\* REROUTE  
WATER  
LINE!

