

HTE# 08-5-21282

Harnett County Department of Public Health

25117

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Roger Dupree / SR1505 PEARIDGE RD PROPERTY LOCATION: SR1505 PEARIDGE RD
 NEW ☐ REPAIR ☐ EXPANSION ☒ SUBDIVISION _____ LOT # _____
 Type of Structure: EX SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: EX System
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement ☐ Yes ☐ No
 Pump Required: ☐ Yes ☐ No ☒ May be required based on final location and elevations of facilities
 Type of Water Supply: ☐ Community ☒ Public ☒ Well Distance from well 50' feet Permit valid for: ☒ Five years
 Permit conditions: NEW TANK TO EXISTING LINES - IF NOT ABLE TO RECONNECT TO OLD DRAIN LINES - NEW SYSTEM WILL BE REQUIRED. ☐ No expiration

Authorized State Agent: James E. Markham Date: 12-15-08 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Roger Dupree / SR1505 PEARIDGE RD PROPERTY LOCATION: SR1505 PEARIDGE RD
 SUBDIVISION _____ LOT # _____
 Facility Type: EX SFD ☐ New ☒ Expansion ☐ Repair
 Basement? ☐ Yes ☒ No Basement Fixtures? ☐ Yes ☐ No
 Type of Wastewater System** EXISTING System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable ☐)
EXISTING (Repair)
 Installation Requirements/Conditions
 Septic Tank Size 1200 gallons Number of trenches EX
 Pump Tank Size _____ gallons Exact length of each trench EX feet Trench Spacing: EX 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: EX 6 inches
 Maximum Trench Depth of: EX inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to $\pm 1/4"$ in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: NEW TANK TO EXISTING LINES - IF NOT ABLE TO RECONNECT - NEW SYSTEM LAYOUT IS REQUIRED. 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 12-15-08
 Construction Authorization Expiration Date: 12-15-13

HTE# 08-5-21282

Permit # 25117

Harnett County Department of Public Health Site Sketch

ISSUED TO: Roger Dupree PROPERTY LOCATION: SR 1505 Pearridge RD
SUBDIVISION _____ LOT # _____

Authorized State Agent: James E. Marshall Date: 12-15-08

- * Existing Septic Tank Under - Existing Patio:
- * New Septic Tank Required minimum -
- * IF NOT ABLE TO RECONNECT TO EXISTING DRAINAGES
NEW DRAINAGES WILL BE REQUIRED.
- * Septic Contractor to contact Environmental Health
About Requirements prior to install of new 1200 Gal Septic Tank.
Ability to reconnect is in question.

