Department of Environmental Health



April 28, 2010

Harnett County Government Complex 307 Cornelius Harnett Boulevard

Mark Neal 255 Asset Parkway Sanford, NC 27332

RE: Harnett County Existing Tank Application #09-5-21628R

Dear Mr. Neal,

The Harnett County Department of Public Health, Environmental Health Division on April 26, 2010, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your *revised* existing tank application. According to your application requesting an addition, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

15A NCAC 18A.1950 a(16) Any swimming pool must be 15' from any part of septic system.

X 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area. Your system is designed for 3 bedrooms only. (350 gpd)

_____ 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line.

You have the following options:

- 1. Pay for soil evaluation so that soil work can be done to see if existing system can be added to, so that it can accommodate four bedrooms.
- 2. Change the use so that 4th bedroom without closet is not a bedroom. Home to stay with a total of 3 bedrooms.

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely, Joe UJ FFHS

Joe West, R. S. REHS Environmental Health Specialist Harnett County Department of Public Health

JW/sgs

ph: 910-893-7547

Lillington, NC 27546

www.harnett.org

fax: 910-893-9371