

-----  
ADDRESS : 4126 RED HILL CHURCH RD SUBDIV:  
CONTRACTOR : PHONE :  
OWNER : HUMPHRIES TERRY W & CONNIE PHONE :  
PARCEL : 02-1507- - -0005- -01-  
APPL NUMBER: 09-50021873 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : 4129 RED HILL CHURCH ROAD  
TAKE 401 TOWARD DUNN. TURN LEFT ON RED  
HILL CHURCH ROAD. GO APPROX 5MI HOME IS  
ON THE RIGHT. BATH ADDITION IS ON THE  
INSIDE OF THE EXT GAR ON THE BACK OF  
PROPERTY.  
T/S: 04/06/2009 03:09 PM RDCONTE ---  
-----

STRUCTURE: 000 000 BATHROOM UPFIT INSIDE EXT DET GAR.  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 SEPTIC - EXISTING? . . . . : NEW TANK  
WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	5/06/09	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765890
	5/06/09	AP	
R425 01	5/12/09	TI	FOUR TRADE ROUGH IN VRU #: 001766294

*5-12 DA - KS*

----- COMMENTS AND NOTES -----  
-----

**Violation Notice  
Do Not Remove**

**Harnett County Inspection Department  
102 East Front St P.O. Box 65  
Lillington, NC 27546  
Phone (910) 893-7525 Fax (910) 893-2793**

**09-50021873**

**May 12, 2009**

- 1. Electrical panel cannot be in a bathroom**
- 2. Panel shall have 3 foot clearance in front of it.**
- 3. Wiring must be fire caulked**
- 4. Tub shall have water in it for test.**

**Ken Slattum**

ADDRESS : 4126 RED HILL CHURCH RD SUBDIV:  
CONTRACTOR : PHONE :  
OWNER : HUMPHRIES TERRY W & CONNIE PHONE :  
PARCEL : 02-1507- - -0005- -01-  
APPL NUMBER: 09-50021873 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : 4129 RED HILL CHURCH ROAD  
TAKE 401 TOWARD DUNN. TURN LEFT ON RED  
HILL CHURCH ROAD. GO APPROX 5MI HOME IS  
ON THE RIGHT. BATH ADDITION IS ON THE  
INSIDE OF THE EXT GAR ON THE BACK OF  
PROPERTY.  
T/S: 04/06/2009 03:09 PM RDCONTE ---

STRUCTURE: 000 000 BATHROOM UPFIT INSIDE EXT DET GAR.

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 SEPTIC - EXISTING? . . . . : NEW TANK  
WATER SUPPLY . . . . . : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	5/06/09	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765890
	5/06/09	AP	
R425 01	5/12/09	KS	FOUR TRADE ROUGH IN VRU #: 001766294
	5/12/09	DA	1. Electrical panel cannot be in bathroom 2. Must have 3 foot clearance in front of panel. 3. Wiring shall be firecaulked. 4. Tub shall be tested.
R425 02	5/27/09	TI	FOUR TRADE ROUGH IN VRU #: 001773159
	5-27	AP	

COMMENTS AND NOTES

~~0177888361~~

-----  
ADDRESS : 4126 RED HILL CHURCH RD SUBDIV:  
CONTRACTOR : PHONE :  
OWNER : HUMPHRIES TERRY W & CONNIE PHONE :  
PARCEL : 02-1507- - -0005- -01-  
APPL NUMBER: 09-50021873 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : 4129 RED HILL CHURCH ROAD  
TAKE 401 TOWARD DUNN. TURN LEFT ON RED  
HILL CHURCH ROAD. GO APPROX 5MI HOME IS  
ON THE RIGHT. BATH ADDITION IS ON THE  
INSIDE OF THE EXT GAR ON THE BACK OF  
PROPERTY.  
T/S: 04/06/2009 03:09 PM RDCONTE ---  
-----

STRUCTURE: 000 000 BATHROOM UPFIT INSIDE EXT DET GAR.  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 SEPTIC - EXISTING? . . . . : NEW TANK  
WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H824 01	5/06/09	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001765890
	5/06/09	AP	
R425 01	5/12/09	KS	FOUR TRADE ROUGH IN VRU #: 001766294
	5/12/09	DA	1. Electrical panel cannot be in bathroom 2. Must have 3 foot clearance in front of panel. 3. Wiring shall be firecaulked. 4. Tub shall be tested.
R425 02	5/27/09	TI	FOUR TRADE ROUGH IN VRU #: 001773159
	5/27/09	CA	
R425 03	5/28/09	KS	FOUR TRADE ROUGH IN VRU #: 001773621
	5/29/09	AP	
R429 01	5/28/09	TI	FOUR TRADE FINAL VRU #: 001773613
	5/27/09	CA	
R429 02	6/19/09	TI	FOUR TRADE FINAL VRU #: 001783778
	<u>6-19</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Bathroom Addition

**PERMIT NUMBERS**

Owner: Terry Humphries

Building Permit No.: 409-50821873

911 Address: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

4126 Red Hill Church

Insulation Permit No.: \_\_\_\_\_

\_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

Date: 6-19-09

MFG. Home: \_\_\_\_\_

K. Slabo

Building Official