

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant: **21873**

Address:

Date Evaluated: **4-17-09**

Proposed Facility:

**EX GARAGE** Design Flow (.1949): **506PD**

Property Size:

Location of Site:

Property Recorded:

- Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1958 Sapro Class	.1944 Restr Horiz	
1	L 2%	0-4	Fill-clay	Fine 1/2 S.P.					.35
		4-20	SL	Gr GL NSNP					
		20-40	SC-clay	Fine 1/2 S.P.	36-38 10/2				
2	L 2%	0-24	SL	Gr GL NSNP				.4	
		24-42	SC-clay	Fine 1/2 S.P.	40 10/2				
3 +	L 3-4%	0-18	SL	Gr GL NSNP				.4	
		18-48	SC-clay	Fine 1/2 S.P.	44 7.5/2				
4.									

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2500	2000
Site LTAR	.35-2.4	.4.

Other Factors (.1946): \_\_\_\_\_  
 Site Classification (.1948): **PS**  
 Evaluated By: \_\_\_\_\_  
 Others Present: