



May 18, 2009

Suntech Exteriors
343 Technology Drive
Garner, NC 27529

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

**Re: Harnett County Land Use Application for Existing Tank #09-5-22032
Dexterfield Lt 2**

To Whom It May Concern,

The Harnett County Department of Public Health, Environmental Health Division on May 15, 2009, evaluated the above referenced property at the site designated on the plat/site plan that accompanied your existing tank application. According to your application requesting an addition, the evaluation was done in accordance with the laws and rules governing wastewater systems in North Carolina General Statute 18A.1950 including related statutes and Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rule.1950 and related rules.

Based on the criteria set out in Title 15A, Subchapter 18A, of the North Carolina Administrative Code, Rules .1950, the evaluation indicated that the site is **UNSUITABLE** for the addition requested. Therefore, your request for an existing tank is **DENIED**. The site is denied based on the following:

_____ 15A NCAC 18A.1950 a (16) Any swimming pool must be 15' from any part of septic system.

_____ 15A NCAC 18.1945 (b) Each lot shall have original septic system plus repair area.

X 15A NCAC 18A.1950 (10) – Any building to be 5' from drain line. *Tank too close to addition.*

If you should have any questions or concerns I can be contacted Monday through Friday from 8am – 9am at 910-893-7547.

Sincerely,

James E. Manhart, III, R.S.
Environmental Health Specialist
Harnett County Department of Public Health

JEM/sgs