



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

8/21/2020

**SUBJECT: CARE09-50022205
BUILDING RESIDENTIAL**

To: WILKINS AARON AND TAMARA #20

Here are the results of all Inspections located at **277 COKESBURY PARK LN:**

Inspection Type: R INSULATION INSPECTION
Scheduled Date/Time: 6/9/2009
Completed Date/Time: 6/9/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: this is for the bonus room floor only*****

Inspection Type: THREE TRADE ROUGH IN
Scheduled Date/Time: 6/9/2009
Completed Date/Time: 6/9/2009
Inspector: Unassigned
Result: DISAPPROVED
Remarks:
Notes: Improper headroom at top of stairs. See attached from DOI and NC residential code. READ CAREFULLY. Ok to cover floor.

Inspection Type: ONE TRADE ROUGH IN
Scheduled Date/Time: 6/11/2009
Completed Date/Time: 6/11/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: this is for the stairway framing only

Inspection Type: THREE TRADE ROUGH IN
Scheduled Date/Time: 6/24/2009
Completed Date/Time: 6/24/2009
Inspector: Unassigned
Result: APPROVED WITH EXCEPT
Remarks:
Notes: Need a smoke detector tied in from existing smoke in bonus room ceiling. Must be 120volt with battery backup and interconnect Will check at insulation inspection





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: R INSULATION INSPECTION
Scheduled Date/Time: 6/25/2009
Completed Date/Time: 6/25/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: T/S: 06/24/2009 12:05 PM NTART -----

Inspection Type: THREE TRADE FINAL
Scheduled Date/Time: 10/20/2009
Completed Date/Time: 11/10/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: T/S: 10/16/2009 03:24 PM VBROWN ----- CUSTOMER REQUEST AM INSP.