

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3 Addition

Permit Numbers

Name: Wilborn Adam

Building: 09-5002278

Address: 54 Robert Broudy Cir.

Electrical: ''

Insulation: ''

Plumbing: ''

Mechanical: ''

MFG Home: ''

Date: 11-22-11

Building Official: T. Michael Ream

PREPARED 11/21/11, 14:13:02
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 11/22/11

ADDRESS . : 54 ROBERT BRANCH CIR SUBDIV: MILL BRANCH
CONTRACTOR : PHONE :
OWNER . . : WILBORN ADAM PHONE : (919) 552-4520
PARCEL . . : 08-0652- - -0097- -24-
APPL NUMBER: 09-50022778 CP ADD & ALTER RESIDENTIAL

DIRECTIONS : T/S: 09/04/2009 02:25 PM JBROCK ----
401 NORTH RIGHT ONTO MILL BRANCH DRIVE
LEFT ONTO ROBERT BRANCH CIR 3RD HOUSE
ON RIGHT

STRUCTURE: 000 000 30X32 FINISH BONUS ROOM BDR/PLAY/OFFICE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : .00 SEPTIC - EXISTING? : EXS
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	12/22/09 12/22/09	KS AP	ONE TRADE ROUGH IN VRU #: 001863828 framing on dormor / need 1st thing in the morning if possible call and let me know the time 919-796-6669
R125 02	3/09/10 3/09/10	BS DA	ONE TRADE ROUGH IN VRU #: 001892410 VOICE MESSAGE LEFT 1. Bath light switch must be at entryway. 2. Move electrical panel to obtain 3' working clearance. OK to insulate
R425 01	5/03/10 5/03/10	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001919604 T/S: 04/30/2010 02:30 PM DJOHNSON ----- T/S: May 03, 2010 10:02 AM BSUTTON -----
R429 01	11/22/11 <i>11-22-11</i>	TI <i>AP-MR</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002163939 T/S: 11/21/2011 01:43 PM VBROWN -----

----- COMMENTS AND NOTES -----