

Harnett County

108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone: Fax:

5/6/2021

SUBJECT: **CARE09-50022778**

BUILDING RESIDENTIAL

To: WILBORN ADAM #24

Here are the results of all Inspections located at **54 ROBERT BRANCH CIR**:

Inspection Type: BLDG PLAN REVIEW

Scheduled Date/Time: 9/9/2009
Completed Date/Time: 9/9/2009
Inspector: Unassigned
Result: DISAPPROVED

Remarks:

Notes: T/S: 09/09/2009 10:45 AM LMCDONAL -----

T/S: 09/09/2009 10:45 AM LMCDONAL ------

Inspection Type: ENVIR. HLTH. CONFIRMATION

Scheduled Date/Time: 9/22/2009
Completed Date/Time: 9/16/2009
Inspector: Unassigned
Result: APPROVED

Remarks:

Notes: T/S: 09/16/2009 11:42 AM SSTEWART -----

Inspection Type: ONE TRADE ROUGH IN

Scheduled Date/Time: 12/22/2009
Completed Date/Time: 12/22/2009
Inspector: Unassigned
Result: APPROVED

Remarks:

Notes: framing on dormor / need 1st thing in the morning if possible call and let me know the time

919-796-6669

Inspection Type: ONE TRADE ROUGH IN

Scheduled Date/Time: 3/9/2010
Completed Date/Time: 3/9/2010
Inspector: Unassigned
Result: DISAPPROVED

Remarks:

Notes:

VOICE MESSAGE LEFT



Harnett County

108 EAST FRONT STREET

LILLINGTON, NC 27546

Phone: Fax:

Inspection Type: 1. Bath light switch must be at entryway. 2. Move electrical panel to obtain 3' working

Scheduled Date/Time: clearance. OK to insulate

Completed Date/Time

Inspection Type: R INSULATION INSPECTION

Scheduled Date/Time: 5/3/2010
Completed Date/Time: 5/3/2010
Inspector: Unassigned
Result: APPROVED

Remarks:

Notes: T/S: May 03, 2010 10:02 AM BSUTTON ------

Inspection Type: FOUR TRADE ROUGH IN

Scheduled Date/Time: 5/3/2010
Completed Date/Time: 5/3/2010
Inspector: Unassigned
Result: APPROVED

Remarks:

Notes:

T/S: 04/30/2010 02:30 PM DJOHNSON -----

T/S: May 03, 2010 10:02 AM BSUTTON -----

Inspection Type: FOUR TRADE FINAL

Scheduled Date/Time: 11/22/2011 Completed Date/Time: 11/22/2011 Inspector: Unassigned Result: APPROVED

Remarks:

Notes: T/S: 11/21/2011 01:43 PM VBROWN -----

T/S: 11/22/2011 12:17 PM MREARIC ----- co issued on addition