



# Permit Inspections Harnett County

**Permit Number: CARE10-50023814**

Description: **21X23 ENCLOSING EXT CARPORT**

Applied: **2/17/2010**

Approved:

Site Address: **6404 OLD STAGE RD N**

Issued: **2/17/2010**

Finalized: **5/20/2010**

City, State Zip Code: **ANGIER, NC 27501**

Status: **CERTIFICATE OF OCCUP**

Applicant: **MUELLER CYNTHIA**

Parent Permit:

Owner: **MUELLER CYNTHIA**

Parent Project:

Contractor: **<NONE>**

Details:

**21X23 ENCLOSING EXT CARPORT COMMENTS: T/S: 02/17/2010 11:39 AM JBROCK ---- 210 EAST RIGHT ON OLD STAGE RD HOUSE ON LEFT AT 6404**

### LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	3/17/2010	3/17/2010	R BLDG FOUND & TEMP SVC POLE	Unassigned	APPROVED	
Notes: T/S: 03/16/2010 12:05 PM VBROWN ----- No foundation to look at. existing carport to be closed in for storage. Not permitted for habitable space.-----						
	4/21/2010	4/21/2010	THREE TRADE ROUGH IN	Unassigned	DISAPPROVED	
Notes: 1.Make up grounds in all boxes. 2. Need receptacles on rear and side walls no more than 12 ' apart. Ok to side/insulate. Will check at insulation inspection						
	4/29/2010	4/29/2010	R INSULATION INSPECTION	Unassigned	APPROVED	
Notes: T/S: 04/28/2010 02:37 PM RDCONTE ----- T/S: April 29, 2010 09:58 AM BSUTTON -----						
	4/29/2010	4/29/2010	THREE TRADE ROUGH IN	Unassigned	APPROVED	
Notes: T/S: 04/28/2010 02:38 PM RDCONTE ----- T/S: April 29, 2010 09:58 AM BSUTTON -----						
	5/20/2010	5/20/2010	THREE TRADE FINAL	Unassigned	APPROVED	
Notes: T/S: 05/19/2010 11:29 AM VBROWN ----- T/S: May 20, 2010 11:05 AM BSUTTON -----						

