

March 31, 2010

ph: 910-893-7547

fax: 910-893-9371

Mary J. Haffner
233 Wexford Drive
Fuquay Varina, NC 27526

RE: Existing Septic System Inspection HTE# 10-5-24069

Dear Ms. Haffner,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal (*\$25.00 fee incurred*)

2. Have system pumped out

3. Replace sanitary T

4. Other – Needs soil scientist report on initial and repair areas to address additions and drive over lines

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart, III, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting