

IMPROVEMENT PERMIT

No 6312

It is ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) ① Currier Builders Inc. New Installation Septic Tank
Property Location: SR 1446 Repairs Nitrification Line
Lot 13 Westford sub.

Number of Bedrooms Proposed: 3 Lot Size: _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community

Distance From Well: 90 ft. All exist. &

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 2 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site as or intended use change.

Date: 04/27/92
Signed: J.H. Bond R.S.
Environmental Health Specialist

VOID AFTER 5 YEARS

