

-----  
ADDRESS . . : 451 SENTER LN  
CONTRACTOR : BETHUNE JR FRED D  
OWNER . . . : HAWKINS ANNIE V  
PARCEL . . . : 01-0535-01- -0100- -18-  
APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
451 SENTER LANE BUNNLEVEL 28323.  
210S, RIGHT ON ANDERSON CREEK SCHOOL  
RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
SENER LANE.

SUBDIV: SENTER HILL 73LOTS  
PHONE : (910) 488-4335  
PHONE :

-----  
**STRUCTURE: 000 000 24X26 ATTACHED GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
PROPOSED USE . . . . : ATT GAR SEPTIC - EXISTING? . . . . : EXISTING  
WATER SUPPLY . . . . : COUNTY

-----  
**PERMIT: CPBP 00 CP BUILDING PERMIT**

| TYP/SQ  | REQUESTED<br>COMPLETED    | INSP<br>RESULT    | DESCRIPTION<br>RESULTS/COMMENTS  |
|---------|---------------------------|-------------------|--|
| B101 01 | 7/27/10<br><u>7/27/10</u> | TI<br><u>DADI</u> | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN ----- |

----- COMMENTS AND NOTES -----

ADDRESS : 451 SENTER LN  
CONTRACTOR : BETHUNE JR FRED D  
OWNER : HAWKINS ANNIE V  
PARCEL : 01-0535-01- -0100- -18-  
APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL

SUBDIV: SENTER HILL 73LOTS  
PHONE : (910) 488-4335  
PHONE :

DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
451 SENTER LANE BUNNLEVEL 28323.  
210S, RIGHT ON ANDERSON CREEK SCHOOL  
RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
SENER LANE.

**STRUCTURE: 000 000 24X26 ATTACHED GARAGE**

FLOOD ZONE : FLOOD ZONE X  
PROPOSED USE : ATT GAR SEPTIC - EXISTING? : EXISTING  
WATER SUPPLY : COUNTY

**PERMIT: CPBP 00 CP BUILDING PERMIT**

| TYP/SQ  | REQUESTED<br>COMPLETED   | INSP<br>RESULT     | DESCRIPTION<br>RESULTS/COMMENTS  |
|---------|--------------------------|--------------------|--|
| B101 01 | 7/27/10<br>7/27/10       | DT<br>DA           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN -----<br>Footing and foundation plans required on site. Trench<br>bottom must be 12 inches below existing grade. Step down<br>required at front trench. Footing must be flat across<br>T/S:07/27/2010 01:24 PM DETAYLOR ----- |
| B101 02 | 7/30/10<br>7/30/10       | DT<br>CA           | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001961366  |
| B101 03 | 8/03/10<br><u>8/3/10</u> | DT<br><u>AP DT</u> | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001963107<br>T/S: 08/02/2010 03:07 PM DJOHNSON -----   |

----- COMMENTS AND NOTES -----

ADDRESS : 451 SENTER LN SUBDIV: SENTER HILL 73LOTS  
CONTRACTOR : BETHUNE JR FRED D PHONE : (910) 488-4335  
OWNER : HAWKINS ANNIE V PHONE :  
PARCEL : 01-0535-01- -0100- -18-  
APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
451 SENTER LANE BUNNLEVEL 28323.  
210S, RIGHT ON ANDERSON CREEK SCHOOL  
RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
SENER LANE.

**STRUCTURE: 000 000 24X26 ATTACHED GARAGE**

FLOOD ZONE : FLOOD ZONE X  
PROPOSED USE : ATT GAR SEPTIC - EXISTING? : EXISTING  
WATER SUPPLY : COUNTY

**PERMIT: CPBP 00 CP BUILDING PERMIT**

| TYP/SQ  | REQUESTED<br>COMPLETED   | INSP<br>RESULT     | DESCRIPTION<br>RESULTS/COMMENTS  |
|---------|--------------------------|--------------------|--|
| B101 01 | 7/27/10<br>7/27/10       | DT<br>DA           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN<br>Footing and foundation plans required on site. Trench bottom must be 12 inches below existing grade. Step down required at front trench. Footing must be flat across<br>T/S:07/27/2010 01:24 PM DETAYLOR |
| B101 02 | 7/30/10<br>7/30/10       | DT<br>CA           | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001961366  |
| B101 03 | 8/03/10<br>8/02/10       | DT<br>AP           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001963107<br>T/S: 08/02/2010 03:07 PM DJOHNSON   |
| B103 01 | 8/09/10<br><u>8/9/10</u> | TI<br><u>AP DT</u> | R*BLDG FOUND & TEMP SVC POLE VRU #: 001965771  |

----- COMMENTS AND NOTES -----

ADDRESS : 451 SENTER LN  
CONTRACTOR : BETHUNE JR FRED D  
OWNER : HAWKINS ANNIE V  
PARCEL : 01-0535-01- -0100- -18-  
APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
451 SENTER LANE BUNNLEVEL 28323.  
210S, RIGHT ON ANDERSON CREEK SCHOOL  
RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
SENER LANE.

SUBDIV: SENTER HILL 73LOTS  
PHONE : (910) 488-4335  
PHONE :

**STRUCTURE: 000 000 24X26 ATTACHED GARAGE**

FLOOD ZONE : FLOOD ZONE X  
PROPOSED USE : ATT GAR  
WATER SUPPLY : COUNTY  
SEPTIC - EXISTING? : EXISTING

**PERMIT: CPBP 00 CP BUILDING PERMIT**

| TYP/SQ  | REQUESTED COMPLETED       | INSP RESULT        | DESCRIPTION RESULTS/COMMENTS   |
|---------|---------------------------|--------------------|--|
| B101 01 | 7/27/10<br>7/27/10        | DT<br>DA           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN -----<br>Footing and foundation plans required on site. Trench bottom must be 12 inches below existing grade. Step down required at front trench. Footing must be flat across<br>T/S:07/27/2010 01:24 PM DETAYLOR ----- |
| B101 02 | 7/30/10<br>7/30/10        | DT<br>CA           | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001961366  |
| B101 03 | 8/03/10<br>8/02/10        | DT<br>AP           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001963107<br>T/S: 08/02/2010 03:07 PM DJOHNSON -----   |
| B103 01 | 8/09/10<br>8/09/10        | DT<br>AP           | R*BLDG FOUND & TEMP SVC POLE VRU #: 001965771  |
| R125 01 | 8/25/10<br><u>8/25/10</u> | TI<br><u>AP DJ</u> | ONE TRADE ROUGH IN VRU #: 001974500  |

**PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL**

| TYP/SQ  | REQUESTED COMPLETED       | INSP RESULT        | DESCRIPTION RESULTS/COMMENTS        |
|---------|---------------------------|--------------------|-------------------------------------|
| R125 01 | 8/25/10<br><u>8/25/10</u> | TI<br><u>AP DJ</u> | ONE TRADE ROUGH IN VRU #: 001974518 |

----- COMMENTS AND NOTES -----

-----

ADDRESS . . : 451 SENTER LN  
 CONTRACTOR : BETHUNE JR FRED D  
 OWNER . . : HAWKINS ANNIE V  
 PARCEL . . : 01-0535-01- -0100- -18-  
 APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL  
 DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
 451 SENTER LANE BUNNLEVEL 28323.  
 210S, RIGHT ON ANDERSON CREEK SCHOOL  
 RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
 SENTER LANE.

-----

**STRUCTURE: 000 000 24X26 ATTACHED GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
 PROPOSED USE . . . . : ATT GAR  
 WATER SUPPLY . . . . : COUNTY

SEPTIC - EXISTING? . . . . : EXISTING

-----

**PERMIT: CPBP 00 CP BUILDING PERMIT**

| TYP/SQ  | REQUESTED<br>COMPLETED    | INSP<br>RESULT     | DESCRIPTION<br>RESULTS/COMMENTS  |
|---------|---------------------------|--------------------|--|
| B101 01 | 7/27/10<br>7/27/10        | DT<br>DA           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN -----<br>Footing and foundation plans required on site. Trench<br>bottom must be 12 inches below existing grade. Step down<br>required at front trench. Footing must be flat across<br>T/S:07/27/2010 01:24 PM DETAYLOR ----- |
| B101 02 | 7/30/10<br>7/30/10        | DT<br>CA           | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001961366  |
| B101 03 | 8/03/10<br>8/02/10        | DT<br>AP           | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001963107<br>T/S: 08/02/2010 03:07 PM DJOHNSON -----   |
| B103 01 | 8/09/10<br>8/09/10        | DT<br>AP           | R*BLDG FOUND & TEMP SVC POLE VRU #: 001965771  |
| R125 01 | 8/25/10<br>8/25/10        | DT<br>AP           | ONE TRADE ROUGH IN VRU #: 001974500<br>Replace vinyl with sheetrock by final.<br>T/S: 08/25/2010 10:53 AM DETAYLOR -----   |
| R229 01 | 9/22/10<br><u>9/22/10</u> | TI<br><u>DA DT</u> | TWO TRADE FINAL VRU #: 001985043   |

----- COMMENTS AND NOTES -----

ADDRESS : 451 SENTER LN  
 CONTRACTOR : BETHUNE JR FRED D  
 OWNER : HAWKINS ANNIE V  
 PARCEL : 01-0535-01- -0100- -18-  
 APPL NUMBER: 10-50024704 CP ADD & ALTER RESIDENTIAL

SUBDIV: SENTER HILL 73LOTS  
 PHONE : (910) 488-4335  
 PHONE :

DIRECTIONS : T/S: 06/28/2010 03:39 PM VBROWN ----  
 451 SENTER LANE BUNNLEVEL 28323.  
 210S, RIGHT ON ANDERSON CREEK SCHOOL  
 RD, RIGHT AT LEMUEL BLACK RD, LEFT AT  
 SENTER LANE.

STRUCTURE: 000 000 24X26 ATTACHED GARAGE

FLOOD ZONE : FLOOD ZONE X

PROPOSED USE : ATT GAR

SEPTIC - EXISTING? : EXISTING

WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

| TYP/SQ  | REQUESTED COMPLETED       | INSP RESULT      | DESCRIPTION RESULTS/COMMENTS   |
|---------|---------------------------|------------------|--|
| B101 01 | 7/27/10<br>7/27/10        | DT<br>DA         | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001959634<br>T/S: 07/26/2010 12:41 PM VBROWN -----<br>Footing and foundation plans required on site. Trench bottom must be 12 inches below existing grade. Step down required at front trench. Footing must be flat across<br>T/S:07/27/2010 01:24 PM DETAYLOR ----- |
| B101 02 | 7/30/10<br>7/30/10        | DT<br>CA         | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001961366  |
| B101 03 | 8/03/10<br>8/02/10        | DT<br>AP         | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001963107<br>T/S: 08/02/2010 03:07 PM DJOHNSON -----   |
| B103 01 | 8/09/10<br>8/09/10        | DT<br>AP         | R*BLDG FOUND & TEMP SVC POLE VRU #: 001965771  |
| R125 01 | 8/25/10<br>8/25/10        | DT<br>AP         | ONE TRADE ROUGH IN VRU #: 001974500<br>Replace vinyl with sheetrock by final.<br>T/S: 08/25/2010 10:53 AM DETAYLOR -----   |
| R229 01 | 9/22/10<br>9/22/10        | DT<br>DA         | TWO TRADE FINAL VRU #: 001985043<br>1. Garage locked, nobody answered door when bell was rung.<br>T/S: 09/22/2010 09:47 AM DETAYLOR -----  |
| R229 02 | 9/23/10<br><u>9/23/10</u> | TI<br><u>APD</u> | TWO TRADE FINAL TIME: 17:00 VRU #: 001986249<br>T/S: 09/23/2010 07:37 AM RDCONTE -----   |

COMMENTS AND NOTES

County of Harnett  
Building Inspections Department  
Planning Services

Certificate of Compliance: \_\_\_ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential (Attached Garage)

Permit Numbers

Name: Annie Hankins

Building: \_\_\_\_\_

Address: 451 Senter Ln

Electrical: 10-50024704

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

Date: 9/23/10

Building Official: RETJE