

-----  
ADDRESS . : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER . . : SLOAN BRUCE & RHONDA PHONE :  
PARCEL . . : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

-----  
**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : .00 SEPTIC - EXISTING? . . . . : EXT  
WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 <i>2-7-11</i>	TI <i>APJH</i>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....---

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER : SLOAN BRUCE & RHONDA PHONE :

PARCEL : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : .00 SEPTIC - EXISTING? : EXT  
WATER SUPPLY : COUNTY

**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 2/07/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ---- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....
B103 01	2/11/11 <i>2-11-11</i>	TI <i>APTH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626 <i>No Card on site</i>

COMMENTS AND NOTES

-----  
ADDRESS : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER : SLOAN BRUCE & RHONDA PHONE :  
PARCEL : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

-----  
**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : .00 SEPTIC - EXISTING? : EXT  
WATER SUPPLY : COUNTY

-----  
**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 2/07/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....---
B103 01	2/11/11 2/11/11	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626 No permit card on site -----
B105 01	2/17/11 <i>2-17-11</i>	TI <i>AP JV</i>	R*OPEN FLOOR TIME: 17:00 VRU #: 002042687 T/S: 02/16/2011 01:10 PM VBROWN -----

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER . . : SLOAN BRUCE & RHONDA PHONE :  
PARCEL . . : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
-----

DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH  
-----

**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : .00 SEPTIC - EXISTING? . . . . : EXT  
WATER SUPPLY . . . . . : COUNTY  
-----

**PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E217 01	2/21/11 <i>2-21-11</i>	TI <i>APJY</i>	R*ELEC RECONNECT TIME: 17:00 VRU #: 002044105 T/S: 02/21/2011 10:05 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 371 STONE CROSS DR SUBDIV: STONE CROSS  
 CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
 OWNER : SLOAN BRUCE & RHONDA PHONE :  
 PARCEL : 01-0535-01- -0100- -80-  
 APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
 DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
 HWY 210 TOWARD SPRING LAKE TURN RIGHT  
 ON OVERHILLS RD TURN RIGHT ONTO STONE  
 CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
 MAPPINT FOR STONE CROSS S/D PH 1  
 PER MAP#99/84, A, B & C.  
 (PER TAX COMMENTS)  
 #01-0505-01-0100-18 WAS SPLIT  
 FROM 01-0535-01-0100 AND NOT  
 THIS PARCEL (COULD NOT DELETE  
 FROM THIS PARCEL)GH

**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : .00 SEPTIC - EXISTING? : EXT  
 WATER SUPPLY : COUNTY

**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 2/07/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....
B103 01	2/11/11 2/11/11	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626 No permit card on site -----
B105 01	2/17/11 2/17/11	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002042687 T/S: 02/16/2011 01:10 PM VBROWN -----
R225 01	3/09/11 <i>3-9-11</i>	TI <i>DA JH</i>	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002051183 T/S: 03/08/2011 10:09 AM JBROCK -----

COMMENTS AND NOTES

-----  
ADDRESS . : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER . . : SLOAN BRUCE & RHONDA PHONE :  
PARCEL . . : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

-----  
**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : .00 SEPTIC - EXISTING? . . . . : EXT  
WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 2/07/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....
B103 01	2/11/11 2/11/11	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626 No permit card on site -----
B105 01	2/17/11 2/17/11	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002042687 T/S: 02/16/2011 01:10 PM VBROWN -----
R225 01	3/09/11 3/09/11	JH <b>DA</b>	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002051183 T/S: 03/08/2011 10:09 AM JBROCK ----- Missing house wrap in gabels. Repair letter for tails cut off existing truss. Frame existing house wall & replace damaged header @ door. Missing baffels. 5)Need to frame down ceiling for required insulation. 6)Need hurricane straps on house side per truss drawings. Need receptacle on back wall of house. replace lag bolts for porch truss they seem to be to short. DO NOT INSULATE
R225 02	3/11/11 <i>3-11-11</i>	TI <i>AP JV</i>	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002052447 T/S: 03/10/2011 10:19 AM JBROCK -----

----- COMMENTS AND NOTES -----

PREPARED 3/14/11, 14:02:10  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 27  
DATE 3/15/11

-----  
ADDRESS . . : 371 STONE CROSS DR  
CONTRACTOR : J.B. RAYNOR CONST CO  
OWNER . . . : SLOAN BRUCE & RHONDA  
PARCEL . . . : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12

SUBDIV: STONE CROSS  
PHONE : (910) 624-8604  
PHONE :

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

-----  
**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : .00 SEPTIC - EXISTING? . . . . : EXT  
WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CP IR 00 CP INSULATION RESIDENTIAL**

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
I129 01	3/15/11	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002053916
	<i>3-15-11</i>	<i>APJA</i>	T/S: 03/14/2011 12:45 PM JBROCK -----

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS : 371 STONE CROSS DR  
CONTRACTOR : J.B. RAYNOR CONST CO  
OWNER : SLOAN BRUCE & RHONDA  
PARCEL : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
HWY 210 TOWARD SPRING LAKE TURN RIGHT  
ON OVERHILLS RD TURN RIGHT ONTO STONE  
CROSS DR LOT 12  
SUBDIV: STONE CROSS  
PHONE : (910) 624-8604  
PHONE :

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
MAPPINT FOR STONE CROSS S/D PH 1  
PER MAP#99/84, A, B & C.  
(PER TAX COMMENTS)  
#01-0505-01-0100-18 WAS SPLIT  
FROM 01-0535-01-0100 AND NOT  
THIS PARCEL (COULD NOT DELETE  
FROM THIS PARCEL)GH

-----  
**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : .00 SEPTIC - EXISTING? : EXT  
WATER SUPPLY : COUNTY

-----  
**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463
	2/07/11	AP	T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....----
B103 01	2/11/11	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626
	2/11/11	AP	No permit card on site -----
B105 01	2/17/11	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002042687
	2/17/11	AP	T/S: 02/16/2011 01:10 PM VBROWN -----
R225 01	3/09/11	JH	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002051183
	3/09/11	DA	T/S: 03/08/2011 10:09 AM JBROCK ----- 1)Missing house wrap in gabels. 2)Repair letter for tails cut off existing truss. 3)Frame existing house wall & replace damaged header @ door. 4)Missing baffels. 5)Need to frame down ceiling for required insulation. 6)Need hurricane straps on house side per truss drawings. 7)Need receptacle on back wall of house. 8)replace lag bolts for porch truss they seem to be to short. DO NOT INSULATE
R225 02	3/11/11	JH	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002052447
	3/11/11	AP	T/S: 03/10/2011 10:19 AM JBROCK -----
R229 01	4/28/11	TI	TWO TRADE FINAL TIME: 17:00 VRU #: 002072593
	<u>4-28-11</u>	<u>DA-MR</u>	T/S: 04/27/2011 08:12 AM JBROCK -----

-----  
COMMENTS AND NOTES  
-----



# **HARNETT COUNTY**

**Building Inspections Dept.  
108 E. Front St.  
Lillington, NC 27546  
910-893-7525**

**DATE: 04-28-11**

**PERMIT # 11-50025832**

**ADDRESS: 370 stone cross**

## **CORRECTIONS NEEDED:**

1. The plumbing pipe to the faucet by the back steps must be insulated
2. The faucet needs to have an anti-siphon backflow preventer
3. The stair openings cannot be more than 4" under stairs and 6" at sides
4. The receptacles in the new room must be tamper-resistant type
5. The porch must have horizontal guards at 18" and 36" when surface is more than 30" from grade

**Mike Rearic      cell# (910) 984- 4772**

ADDRESS : 371 STONE CROSS DR  
 CONTRACTOR : J.B. RAYNOR CONST CO  
 OWNER : SLOAN BRUCE & RHONDA  
 PARCEL : 01-0535-01- -0100- -80-  
 APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
 DIRECTIONS : T/S: 01/04/2011 02:11 PM JBROCK ----  
 HWY 210 TOWARD SPRING LAKE TURN RIGHT  
 ON OVERHILLS RD TURN RIGHT ONTO STONE  
 CROSS DR LOT 12

SUBDIV: STONE CROSS  
 PHONE : (910) 624-8604  
 PHONE :

LAND NOTES : LXMN 4/20/00 32.19 AC DED FROM THIS PARCEL PER  
 MAPPINT FOR STONE CROSS S/D PH 1  
 PER MAP#99/84, A, B & C.  
 (PER TAX COMMENTS)  
 #01-0505-01-0100-18 WAS SPLIT  
 FROM 01-0535-01-0100 AND NOT  
 THIS PARCEL (COULD NOT DELETE  
 FROM THIS PARCEL)GH

**STRUCTURE: 000 000 12X24 EXER ROOM/12X12 ROOF OVER EXT DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : .00 SEPTIC - EXISTING? : EXT  
 WATER SUPPLY : COUNTY

**PERMIT: CPBP 00 CP BUILDING PERMIT**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/07/11 2/07/11	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002037463 T/S: 02/02/2011 04:44 PM VBROWN ----- CUSTOMER WANTS YOU TO CALL THEM 1HR BEFORE ARIVAL SO THEY CAN MEET YOU ON SITE 910 624 8604 J D RAYNOR. PLEASE CALL MR RAYNOR BEFORE GOING OUT AT 624-8604.....
B103 01	2/11/11 2/11/11	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002039626 No permit card on site -----
B105 01	2/17/11 2/17/11	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002042687 T/S: 02/16/2011 01:10 PM VBROWN -----
R225 01	3/09/11 3/09/11	JH DA	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002051183 T/S: 03/08/2011 10:09 AM JBROCK ----- 1)Missing house wrap in gabels. 2)Repair letter for tails cut off existing truss. 3)Frame existing house wall & replace damaged header @ door. 4)Missing baffels. 5)Need to frame down ceiling for required insulation. 6)Need hurricane straps on house side per truss drawings. 7)Need receptacle on back wall of house. 8)replace lag bolts for porch truss they seem to be to short. DO NOT INSULATE
R225 02	3/11/11 3/11/11	JH AP	TWO TRADE ROUGH IN TIME: 17:00 VRU #: 002052447 T/S: 03/10/2011 10:19 AM JBROCK -----
R229 01	4/28/11 4/28/11	MR DA	TWO TRADE FINAL TIME: 17:00 VRU #: 002072593 T/S: 04/27/2011 08:12 AM JBROCK ----- T/S: 04/28/2011 12:55 PM MREARIC ----- water line to outside faucet must be insulated faucet needs an anti-siphon device

PREPARED 5/02/11, 13:58:22  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 11  
DATE 5/03/11

-----  
ADDRESS : 371 STONE CROSS DR SUBDIV: STONE CROSS  
CONTRACTOR : J.B. RAYNOR CONST CO PHONE : (910) 624-8604  
OWNER : SLOAN BRUCE & RHONDA PHONE :  
PARCEL : 01-0535-01- -0100- -80-  
APPL NUMBER: 11-50025832 CP ADD & ALTER RESIDENTIAL  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R229 02	5/03/11	TI	stair openings cannot be more than 4" under stairs and 6" on sides receptacles to be tamper-resistant porch must have orizontal guards at 18 and 36" TWO TRADE FINAL TIME: 17:00 VRU #: 002074771 T/S: 05/02/2011 11:16 AM JBROCK

53-11 APJH

----- COMMENTS AND NOTES -----

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_\_\_ Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD addition

Name: Bence & Rhonda Sloan

Address: 371 Stone Cross Dr

\_\_\_\_\_

\_\_\_\_\_

Date: 5-3-11

Building Official: \_\_\_\_\_

James T. Hall

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

50-2587  
11