

Harnett County Government Complex
307 Cornelius Harnett Boulevard
Lillington, NC 27546

February 29, 2012

Wade Vuncannon
101 Parker Drive
Fuquay Varina , NC 27526

ph: 910-893-7547
fax: 910-893-9371

RE: Existing Septic System Inspection HTE# 12-5-28424

Dear Mr. Vuncannon,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal (\$25.00 fee incurred)


2. Have system pumped out

3. Replace sanitary T

4. Other – Incorrect lid was uncovered please uncover correct lid. Also, the distribution box needs to be located along with your existing drain field to determine if it can accommodate the additional proposed bedrooms. Please contact me if you have any questions.

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart, III, R.E.H.S.
Environmental Health Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting