

ADDRESS : 406 RUTH CIR

SUBDIV: BALLARD WOODS

CONTRACTOR : ARCHADECK OF RALEIGH

PHONE : (919) 733-2533

OWNER : HAWKINS NICLOE M &

PHONE : (919) 346-0109

PARCEL : 08-0654- - -0292- -60-

APPL NUMBER: 12-50029426 CP ADD & ALTER RESIDENTIAL

DIRECTIONS : T/S: 07/20/2012 02:05 PM JBROCK ----
TAKE 401 N TURN R ON BALLARD RD TURN R
ON JOSEPH ALEXANDER DR TURN LEFT ON
RUTH CIR

LAND NOTES : LXMN 12/30/04 SPLIT FROM 08-0654-0292-38

STRUCTURE: 000 000 22X18 SCREEN PORCH / DECK

FLOOD ZONE : FLOOD ZONE X

SEPTIC - EXISTING? : EXT

WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/12	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002268236
	8/21/12	AP	T/S: August 21, 2012 12:51 PM BSUTTON -----
B101 02	8/24/12	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002270494

8-24-12

ADBS

** See notes on HTE*

COMMENTS AND NOTES

*2nd footing needed
Customer talked w/
Brad*

ADDRESS . . : 406 RUTH CIR SUBDIV: BALLARD WOODS
 CONTRACTOR : ARCHADECK OF RALEIGH PHONE : (919) 733-2533
 OWNER . . : HAWKINS NICLOE M & PHONE : (919) 346-0109
 PARCEL . . : 08-0654- - -0292- -60-
 APPL NUMBER: 12-50029426 CP ADD & ALTER RESIDENTIAL
 DIRECTIONS : T/S: 07/20/2012 02:05 PM JBROCK ----
 TAKE 401 N TURN R ON BALLARD RD TURN R
 ON JOSEPH ALEXANDER DR TURN LEFT ON
 RUTH CIR
 LAND NOTES : LXMN 12/30/04 SPLIT FROM 08-0654-0292-38

STRUCTURE: 000 000 22X18 SCREEN PORCH / DECK

FLOOD ZONE : FLOOD ZONE X
 SEPTIC - EXISTING? : EXT WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/21/12	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002268236
	8/21/12	AP	T/S: August 21, 2012 12:51 PM BSUTTON -----
B101 02	8/24/12	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002270494
	8/24/12	AP	T/S: August 24, 2012 08:32 AM BSUTTON ----- New footing is approved, however all dimensional lumber that is in contact with the ground must be rated for ground contact. The lumber on site IS NOT. All tags must be visible at time of inspection.
B105 01	8/29/12	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 002272045

8-29-12 TI ARBS

----- COMMENTS AND NOTES -----