

HTE# 12-5-29959

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Patio Enclosures Inc PHONE # 919-467-2846

ADDRESS 1030 Monroisville ^{Park} Way Monroisville NC 27560

NAME OF MOBILE HOME PARK OR S/D Victoria Hills lot 51

NAME OF OWNER (IF DIFFERENT) Timmy Kern

ADDRESS OF OWNER (IF DIFFERENT) 41 Delmar CT F.V. NC. 27526

PROPERTY LOCATION: STATE ROAD NAME AND # SR 1440 Lafayette Rd

PURPOSE OF INSPECTION: Sun Room 12x14'

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Markant ^{SE 26119}
Signature of Environmental Health Specialist

11-7-12
Date