



Harnett County
 108 EAST FRONT STREET
 LILLINGTON, NC 27546
 Phone:
 Fax:

8/21/2020

**SUBJECT: CARE12-50030071
 BUILDING RESIDENTIAL**

To: WILKINS AARON

Here are the results of all Inspections located at **277 COKESBURY PARK LN:**

Inspection Type: ONE TRADE FINAL
 Scheduled Date/Time: 11/19/2012
 Completed Date/Time: 11/19/2012
 Inspector: Unassigned
 Result: DISAPPROVED
 Remarks:
 Notes: T/S: 11/16/2012 11:09 AM VBROWN -----
 T/S: November 19, 2012 10:58 AM BSUTTON ----- Tie headers back into house wall. joists on deck parallel with roof header must be double, and need an intermediate post and footing. Need collar ties in upper third of rafters (every third one)

Inspection Type: ONE TRADE ROUGH IN
 Scheduled Date/Time: 11/29/2012
 Completed Date/Time: 11/29/2012
 Inspector: Unassigned
 Result: APPROVED
 Remarks:
 Notes: T/S: 11/29/2012 11:39 AM DJOHNSON -----
 T/S: November 29, 2012 11:43 AM BSUTTON -----

Inspection Type: ONE TRADE FINAL
 Scheduled Date/Time: 11/29/2012
 Completed Date/Time: 11/29/2012
 Inspector: Unassigned
 Result: CANCELLED
 Remarks:
 Notes: T/S: 11/28/2012 02:19 PM VBROWN ----- T/S: 11/29/2012 11:39 AM DJOHNSON -----
 T/S: November 29, 2012 11:43 AM BSUTTON -----





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ONE TRADE FINAL

Scheduled Date/Time: 1/15/2013

Completed Date/Time: 1/15/2013

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

T/S: 01/14/2013 08:39 AM VBROWN -----

T/S: January 15, 2013 09:39 AM BSUTTON ----- Final Inspection Approved