

HTE# 13-5-30420

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Chapman-Wilson PHONE # 910.928.8738

ADDRESS 606 Hope Mills Rd - Fayetteville, NC 28304

NAME OF MOBILE HOME PARK OR S/D Buffalo Lakes Tr. 421

NAME OF OWNER (IF DIFFERENT) Anthony Aguilar

ADDRESS OF OWNER (IF DIFFERENT) 125 Duck Ln, Sanford

PROPERTY LOCATION: STATE ROAD NAME AND # Vic Keith Rd.

PURPOSE OF INSPECTION: 30x30 concrete slab - patio

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

- THIS INSPECTION IS VOID IF:
- (1) the intended use of the septic system should change, and/or
 - (2) the system should fail or malfunction, and/or
 - (3) the owner or tenant of the property changes, and/or
 - (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

Graham N. Byrd, R.E.N.S. (sgs) 1/22/13
Signature of Environmental Health Specialist Date