



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

10/15/2019

**SUBJECT: CARE13-50030431
BUILDING RESIDENTIAL**

To: BRIGGS DAVID M

Here are the results of all Inspections located at **40 BREEZEWAY LN:**

Inspection Type: THREE TRADE ROUGH IN
Scheduled Date/Time: 2/7/2013
Completed Date/Time: 2/8/2013
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: T/S: 02/08/2013 07:11 AM FSPIVEY -----

Inspection Type: THREE TRADE FINAL
Scheduled Date/Time: 3/31/2015
Completed Date/Time: 3/31/2015
Inspector: Unassigned
Result: DISAPPROVED
Remarks:
Notes: T/S: 03/30/2015 12:39 PM DJOHNSON ----- CUSTOMER IS MILITARY AND HAS BEEN OUT OF THE COUNTRY FOR SOME TIME. I DID NOT RECHARGE PERMIT FEE
1-SEAL HOLE IN WALL AROUND WIRES BESIDE A/C RETURN 2-NEED LIGHT AND RECP INSIDE AIR HANDELER ROOM 3- DOORS TO AIR HANDELER ROOM NEED INSULATION AND SEALS 4- NO INSULATION INSPECTION ON FILE ALSO MISSING AIR BARRIERS PER CODE ON ALL KNEE WALLS 5-ALL ATTIC ACESS HOLES NEED TO BE INSULATED AND SEAL, WEATHERSTRIP PER CODE 6- NEED C/O AND SMOKE DETECTOR

