

Initial Application Date: 11-20-13

Application # 13500 32514

CU# _____

COUNTY OF HARNETT RESIDENTIAL LAND USE APPLICATION

Central Permitting 108 E. Front Street, Lillington, NC 27546 Phone: (910) 893-7525 ext:2 Fax: (910) 893-2793 www.harnett.org/permits

****A RECORDED SURVEY MAP, RECORDED DEED (OR OFFER TO PURCHASE) & SITE PLAN ARE REQUIRED WHEN SUBMITTING A LAND USE APPLICATION****

LANDOWNER: Michael J. Kesick Mailing Address: 205 CREEKSIDE DRIVE
City: Angier State: NC Zip: 27501 Contact No: 919-673-1283 Email: MIKESICK@Embarrasmail.com

APPLICANT: _____ Mailing Address: _____
City: _____ State: _____ Zip: _____ Contact No: _____ Email: _____
**Please fill out applicant information if different than landowner*

CONTACT NAME APPLYING IN OFFICE: _____ Phone # _____

PROPERTY LOCATION: Subdivision: Creek side Farm Lot #: C Lot Size: 5.07
State Road, #: _____ State Road Name: Charleston Spring Rd Map Book & Page: PCMF, 162-2
Parcel: 04 0664 0005 03 PIN: 0664-81-8224,000
Zoning: RA2 Flood Zone: X Watershed: IV Deed Book & Page: 1069, 797 Power Company*: _____

**New structures with Progress Energy as service provider need to supply premise number _____ from Progress Energy.*

PROPOSED USE:

- SFD: (Size _____ x _____) # Bedrooms: _____ # Baths: _____ Basement (w/wo bath): _____ Garage: _____ Deck: _____ Crawl Space: _____ Slab: _____ Slab: _____
(Is the bonus room finished? () yes () no w/ a closet? () yes () no (if yes add in with # bedrooms))
- Mod: (Size _____ x _____) # Bedrooms _____ # Baths _____ Basement (w/wo bath) _____ Garage: _____ Site Built Deck: _____ On Frame _____ Off Frame _____
(Is the second floor finished? () yes () no Any other site built additions? () yes () no)
- Manufactured Home: _____ SW _____ DW _____ TW (Size _____ x _____) # Bedrooms: _____ Garage: _____ (site built? _____) Deck: _____ (site built? _____)
- Duplex: (Size _____ x _____) No. Buildings: _____ No. Bedrooms Per Unit: _____
- Home Occupation: # Rooms: _____ Use: _____ Hours of Operation: _____ #Employees: _____
- Addition/Accessory/Other: (Size 32 x 35) Use: Fin Bonus Room 3Bdr - 5 Bdr Closets in addition? () yes () no

Water Supply: County _____ Existing Well _____ New Well (# of dwellings using well _____) ***Must have operable water before final**
Sewage Supply: _____ New Septic Tank (Complete Checklist) Existing Septic Tank (Complete Checklist) _____ County Sewer 30' SEWER EASEMENT
Does owner of this tract of land, own land that contains a manufactured home within five hundred feet (500') of tract listed above? () yes () no
Does the property contain any easements whether underground or overhead () yes () no
Structures (existing or proposed): Single family dwellings: 1 Manufactured Homes: _____ Other (specify): _____

Required Residential Property Line Setbacks:

	Minimum	Actual
Front	_____	_____
Rear	_____	_____
Closest Side	_____	_____
Sidestreet/corner lot	_____	_____
Nearest Building on same lot	_____	_____

Comments: Fin Up Stairs No permits Pulled, Double Permit Fees, 1 \$100 Exist Tank Eng 3bdr to -> 5 Bdr once AP, Double Permit Fee + Eng

SPECIFIC DIRECTIONS TO THE PROPERTY FROM LILLINGTON: NORTH ON 210. TURN LEFT ON
SS NORTH FIRST LEFT ON WEST WILLIAMS ST. A 1.5 MILES TURN
LEFT ON CREEKSIDE DRIVE 2ND HOUSE ON LEFT SEPTIC TANK
IS ON RIGHT SIDE OF HOUSE IF YOU ARE FACING IT THROUGH GATE
& BY A/C UNIT SEPTIC FIELD IS IN FRONT YARD AND HORSE
PASTURE


If permits are granted I agree to conform to all ordinances and laws of the State of North Carolina regulating such work and the specifications of plans submitted. I hereby state that foregoing statements are accurate and correct to the best of my knowledge. Permit subject to revocation if false information is provided.

[Handwritten Signature]
 Signature of Owner or Owner's Agent

11-17-2013
 Date

It is the owner/applicants responsibility to provide the county with any applicable information about the subject property, including but not limited to: boundary information, house location, underground or overhead easements, etc. The county or its employees are not responsible for any incorrect or missing information that is contained within these applications.

This application expires 6 months from the initial date if permits have not been issued



NAME: Michael Kesick

APPLICATION #: _____

This application to be filled out when applying for a septic system inspection.

County Health Department Application for Improvement Permit and/or Authorization to Construct

IF THE INFORMATION IN THIS APPLICATION IS FALSIFIED, CHANGED, OR THE SITE IS ALTERED, THEN THE IMPROVEMENT PERMIT OR AUTHORIZATION TO CONSTRUCT SHALL BECOME INVALID. The permit is valid for either 60 months or without expiration depending upon documentation submitted. (Complete site plan = 60 months; Complete plat = without expiration)

910-893-7525 option 1

CONFIRMATION # _____

Environmental Health New Septic System Code 800

- **All property irons must be made visible.** Place "pink property flags" on each corner iron of lot. All property lines must be clearly flagged approximately every 50 feet between corners.
- Place "orange house corner flags" at each corner of the proposed structure. Also flag driveways, garages, decks, out buildings, swimming pools, etc. Place flags per site plan developed at/for Central Permitting.
- Place orange Environmental Health card in location that is easily viewed from road to assist in locating property.
- If property is thickly wooded, Environmental Health requires that you clean out the undergrowth to allow the soil evaluation to be performed. Inspectors should be able to walk freely around site. **Do not grade property.**
- **All lots to be addressed within 10 business days after confirmation. \$25.00 return trip fee may be incurred for failure to uncover outlet lid, mark house corners and property lines, etc. once lot confirmed ready.**
- After preparing proposed site call the voice permitting system at 910-893-7525 option 1 to schedule and use code 800 (after selecting notification permit if multiple permits exist) for Environmental Health inspection. Please note confirmation number given at end of recording for proof of request.
- Use Click2Gov or IVR to verify results. Once approved, proceed to Central Permitting for permits.

Environmental Health Existing Tank Inspections Code 800

- Follow above instructions for placing flags and card on property.
- Prepare for inspection by removing soil over outlet end of tank as diagram indicates, and lift lid straight up (if possible) and then **put lid back in place.** (Unless inspection is for a septic tank in a mobile home park)
- **DO NOT LEAVE LIDS OFF OF SEPTIC TANK**
- After uncovering outlet end call the voice permitting system at 910-893-7525 option 1 & select notification permit if multiple permits, then use code 800 for Environmental Health inspection. Please note confirmation number given at end of recording for proof of request.
- Use Click2Gov or IVR to hear results. Once approved, proceed to Central Permitting for remaining permits.

SEPTIC

If applying for authorization to construct please indicate desired system type(s): can be ranked in order of preference, must choose one.

- Accepted Innovative Conventional Any
 Alternative Other _____

The applicant shall notify the local health department upon submittal of this application if any of the following apply to the property in question. If the answer is "yes", applicant **MUST ATTACH SUPPORTING DOCUMENTATION**:

- YES NO Does the site contain any Jurisdictional Wetlands?
 YES NO Do you plan to have an irrigation system now or in the future?
 YES NO Does or will the building contain any drains? Please explain. _____
 YES NO Are there any existing wells, springs, waterlines or Wastewater Systems on this property?
 YES NO Is any wastewater going to be generated on the site other than domestic sewage?
 YES NO Is the site subject to approval by any other Public Agency?
 YES NO Are there any Easements or Right of Ways on this property? Runway
 YES NO Does the site contain any existing water, cable, phone or underground electric lines?

If yes please call No Cuts at 800-632-4949 to locate the lines. This is a free service.


I Have Read This Application And Certify That The Information Provided Herein Is True, Complete And Correct. Authorized County And State Officials Are Granted Right Of Entry To Conduct Necessary Inspections To Determine Compliance With Applicable Laws And Rules. I Understand That I Am Solely Responsible For The Proper Identification And Labeling Of All Property Lines And Corners And Making The Site Accessible So That A Complete Site Evaluation Can Be Performed.

Michael Kesick

PROPERTY OWNERS OR OWNERS LEGAL REPRESENTATIVE SIGNATURE (REQUIRED)

11-17-2013

DATE




Harnett
COUNTY
NORTH CAROLINA
strong roots • new growth


HARNETT COUNTY ENVIROMENTAL HEALTH


SEPTIC TANK DIAGRAM

HOW TO PROPERLY IDENTIFY YOUR TANK'S LID(S)


DIAGRAM OF A TYPICAL SEPTIC TANK



 **SQUARE** (Shown on diagram)

 **RECTANGLE** (Older tanks)

 **ROUND**




HARNETT COUNTY ENVIRONMENTAL HEALTH SITE PREPARATION

**Harnett
COUNTY**

NORTH CAROLINA
strong roots • new growth

HOW TO PROPERLY MARK PROPERTY FOR SOIL EVALUATION



COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential (32x35, Bonus Room BR3-4)

Permit Numbers

Name: Michael J & Lori Ann Kesick

Building: _____

Electrical: _____

Insulation: _____


Plumbing: _____

Mechanical: 1350032514

MFG Home: _____

Address: 205 Creekside Dr

Date: 1-15-14

Building Official: 

ADDRESS : 205 CREEKSIDE DR
CONTRACTOR :
OWNER : KESICK MICHAEL J & LORI ANN
PARCEL : 04-0664- - -0005- -03-
APPL NUMBER: 13-50032514 CP ADD & ALTER RESIDENTIAL
DIRECTIONS : T/S: 11/21/2013 09:57 AM VBROWN ----
205 CREEK SIDE DRIVE ANGIER 27501.
401N RIGHT ON CHALYBEATE SPRINGS RD.
TAKE THIS ROUTE BECAUSE OF THE BRIDGE
CONSTRUCTION IT IS ON THIS SIDE OF
CROSS LINK SUB DIV. GO PAST CROSS LINK
SUB DIV 500 FT TOWARDS BRIDGE
CONSTRUCTION CREEK SIDE DRIVE ON RIGHT
PAST CROSS LINK SUB DIV.

SUBDIV: CREEK SIDE FARMS
PHONE :
PHONE : (919) 639-0521

*no insulation
needed.*

STRUCTURE: 000 000 32X35 FIN BON ROOM CHG # BDR FROM 3-4

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 SEPTIC - EXISTING? : EXIST
WATER SUPPLY : COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R425 01	12/27/13 12/27/13	KS AE	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002480085 T/S: 12/23/2013 11:38 AM VBROWN T/S: 12/27/2013 10:28 AM KSLATTUM 1. Need arc fault breakers installed. 2. Need smoke detectors in bedrooms.
R429 01	1/15/14 <u>1/15/14</u>	TI <u>APDT</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002483956 need afternoon inspection

COMMENTS AND NOTES