COUNTY OF HA Building Inspections Planning Ser	Department vices
	Occupancy: Y
his certifies at the time of issuance, this structure was in compliance w	ith the various ordinances of the County of Harriott and the
Iorth Carolina State Building Codes. For the following:	Permit Numbers
Jse Classification: Kesiden tial	. 1
Name: Javier Ledesma Montoya	Building:
	Electrical:
Address: 62 Katz Ln	Insulation:
	Plumbing:
	Mechanical:
	MFG Home:
Date: 17 - 29-14 Building Officia	al: / 2 E / Q
Date: 12-27-11	

PREPARED 12/23/14, 14:52:28
Harnett County

INSPECTION TICKET INSPECTOR: IVR

PAGE

DATE 12/29/14

ADDRESS . : 62 KATZ LN SUBDIV:

SUBDIV: PHONE : PHONE :

CONTRACTOR :

OWNER . . : MONTOYA JAVIER LEDESMA

PARCEL . : 04-0672- - -0209- -14-

APPL NUMBER: 14-50033484 CP ADD & ALTER RESIDENTIAL DIRECTIONS: T/S: 04/23/2014 03:02 PM DJOHNSON --

SANDY GROVE SEC 2 LOT 11

62 KATZ LN

4-14-14 CUSTOMER NEEDS TO PROVIDE A RECORDED SURVEY SITE PLAN SHOWING HOUSE, ADDITION, ELECTRICAL LINES, AND DISTANCES FROM ALL. WILL THEN NEED TO BE CHECKED BY JAY TO SEE IF IT NEEDS TO BE FORWARED TO NORWOOD WEST AT DUKE

BUTES CKRd
NOTETH OF WITHIN WILL YOU

ENERGY.

STRUCTURE: 000 000 24X34 GARAGE WITH BEDROOM ABOVE GARAGE

FLOOD ZONE . . . : FLOOD ZONE X

BEDROOMS 4.00 SEPTIC - EXISTING? : YES

WATER SUPPLY COUNTY

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/27/14	DT	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002592475
	10/28/14	AP	T/S: 10/28/2014 01:10 PM DETAYLOR
B103 01	10/31/14	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002594455
	10/31/14	AP	T/S: 10/31/2014 09:20 AM DETAYLOR
R425 01	11/24/14	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002602019
	11/24/14	DA	T/S: 11/21/2014 01:00 PM VBROWN
			T/S: 11/24/2014 01:27 PM KSLATTUM
			Need protection plates on rear wall top plate. Large ones,
			2. Need to raise hvac platform for insulation ok to side
			and insulate
R425 02	11/26/14	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002603009
	11/26/14	AP	T/S: 11/25/2014 11:54 AM VBROWN
			T/S: 11/26/2014 04:11 PM KSLATTUM
R429 01	12/29/14	AP M	FOUR TRADE FINAL TIME: 17:00 VRU #: 002612216