



Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547

fax: 910-893-9371

August 13, 2014

David Dozier
1508 Mycenae Place
Fuquay Varina, NC 27526

RE: Existing Septic System Inspection HTE# 14-5-34310

Mr. Dozier,

An attempt was made to evaluate your property for the purpose of issuing an Existing Tank Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Uncover outlet lid on septic tank and break seal (**\$25.00 fee incurred**)
- 2. Have system pumped out
- 3. Replace sanitary T
- 4. Other – Uncover septic tank and find drain field. Contact me please at the number listed.**

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

James E. Manhart, III, R.E.H.S.
Environmental Health OSWW Specialist
Harnett County Department of Public Health
Environmental Health

JEM/sgs
Copy - Central Permitting