



Permit Inspections Harnett County

Permit Number: CARE15-50036775

Description: 14X25 BATH & CLOSET ADD - CLOSING IN 16X16 PORCH

Applied: **8/3/2015**

Approved:

Site Address: **3480 OLD STAGE RD N**

Issued: **8/3/2015**

Finalized: **5/24/2016**

City, State Zip Code: **ANGIER, NC 27501**

Status: **CERTIFICATE OF OCCUP**

Applicant: **JOHNSON BRANDON**

Parent Permit:

Owner: **JOHNSON BRANDON L**

Parent Project:

Contractor: **<NONE>**

Details:

14X25 BATH & CLOSET ADD - CLOSING IN 16X16 PORCH COMMENTS: T/S: 08/03/2015 09:34 AM JBROCK ---- 210 N R ON 55 TOWARD COATS L ON OLD STAGE RD 4TH HOUSE ON THE R GRAY HOUSE WITH BLACK METAL ROOF

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	8/17/2015	8/28/2015	ENVIR. HLTH. CONFIRMATION	Unassigned	APPROVED	
Notes: T/S: 08/28/2015 09:41 AM S STEWART -----						
	9/2/2015	9/2/2015	R BLDG FOOTING / TEMP SVC POLE	Unassigned	APPROVED	
Notes: If there are any issues please give me a call Thanks Brandon 9193890928 T/S: September 02, 2015 09:50 AM BSUTTON -----						
	9/14/2015	9/14/2015	R BLDG FOUND & TEMP SVC POLE	Unassigned	APPROVED	
Notes: T/S: September 14, 2015 11:18 AM BSUTTON ----- Minimum access height is 18 inches. Minimum underfloor clearance to floor system is 16 inches. May need to remove soil at foundation adjacent to rear door. Will check both at open floor inspection.						
	9/23/2015	9/23/2015	R OPEN FLOOR	Unassigned	APPROVED	
Notes: If there are any problems please give me a call Thanks Brandon 9193890928 T/S: 09/23/2015 11:39 AM DETAYLOR -----						
	11/13/2015	11/13/2015	FOUR TRADE ROUGH IN	Unassigned	APPROVED	
Notes: Inspector if you will give me a call 30 minutes before you arrive I will meet you on site Thanks Brandon 919-389-0928 T/S: November 13, 2015 11:59 AM BSUTTON -----						
	11/18/2015	11/18/2015	R INSULATION INSPECTION	Unassigned	APPROVED	
Notes: Key for the front door will be in electrical box on front porch if you have any problems give me a call Thanks 9193890928 T/S: 11/18/2015 10:12 AM DETAYLOR -----						





Permit Inspections Harnett County

	3/18/2016	3/18/2016	ENVIR. OPERATIONS PERMIT	Unassigned	APPROVED	
--	-----------	-----------	--------------------------------	------------	----------	--

Notes:
 T/S: 03/21/2016 12:10 PM S STEWART -----
 T/S: 03/21/2016 12:10 PM S STEWART -----

	5/4/2016	5/4/2016	FOUR TRADE FINAL	Unassigned	CANCELLED	
--	----------	----------	---------------------	------------	-----------	--

Notes:
 If you can give me a call 30 min before arriving I can meet you here Thanks Brandon
 T/S: 05/04/2016 08:11 AM LBENNETT -----

	5/24/2016	5/24/2016	FOUR TRADE FINAL	Unassigned	APPROVED	
--	-----------	-----------	---------------------	------------	----------	--

Notes:
 Please give me a call at 9193890928 and I will meet you at the residence to let you inside Thanks Brandon
 T/S: 05/24/2016 12:22 PM DETAYLOR -----

