



Permit Inspections

Harnett County

Permit Number: **CARE15-50037159**

Description: **16X12 SCREENED IN PORCH (EXISTING DECK)**

Applied: **9/22/2015**

Approved:

Site Address: **288 JOSEPH ALEXANDER DR**

Issued: **9/29/2015**

Finalized: **2/19/2016**

City, State Zip Code: **FUQUAY-VARINA, NC 27526**

Status: **CERTIFICATE OF OCCUP**

Applicant: **GRIFFIN JAMES & LORNA**

Parent Permit:

Owner: **GRIFFIN JAMES V & LORNA N**

Parent Project:

Contractor: **<NONE>**

Details:

16X12 SCREENED IN PORCH (EXISTING DECK) COMMENTS: T/S: 09/22/2015 11:26 AM LBENNETT -- 288 JOSEPH ALEXANDER DRIVE - BALLARD WOODS 401 N 2 MI - TURN RIGHT ON BALLARD RD - BALLARD WOODS ON RIGHT - LAST HOUSE ON THE RIGHT

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	10/19/2015	10/19/2015	ONE TRADE ROUGH IN	Unassigned	DISAPPROVED	
Notes: T/S: 10/19/2015 09:38 AM LBENNETT ----- T/S: October 19, 2015 09:38 AM BSUTTON ----- 1. Header supporting rafters must be double 2x8 solidly supported on top of posts, or through bolted into the face of posts with 1/2 inch through bolts/nuts/washers. 2. Shingles may not be used on roof pitch below 2:12						
	10/19/2015	10/19/2015	ONE TRADE FINAL	Unassigned	CANCELLED	
Notes: T/S: 10/16/2015 04:49 PM LBENNETT ----- WOULD LIKE EARLY AS POSSIBLE T/S: October 19, 2015 01:50 PM BSUTTON -----						
	10/21/2015	10/21/2015	ONE TRADE ROUGH IN	Unassigned	APPROVED	
Notes: T/S: 10/20/2015 10:39 AM DJOHNSON ----- T/S: October 21, 2015 09:46 AM BSUTTON -----						
	2/19/2016	2/19/2016	ONE TRADE FINAL	Unassigned	APPROVED	
Notes: T/S: February 19, 2016 11:04 AM BSUTTON -----						