

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Larry Paul Jernigan

Address: 592 Guy Rd

(30x27 Addition)

Date: 11-19-16

Building Official: 

Permit Numbers

Building: 1650039336

Electrical: " "

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

ADDRESS . . : 592 GUY RD
 CONTRACTOR :
 OWNER . . : JERNIGAN LARRY PAUL
 PARCEL . . : 04-0682- - -0150- -01-
 APPL NUMBER: 16-50039336 CP ADD & ALTER RESIDENTIAL
 DIRECTIONS : 592 GUY RD N MAIN ST/ R@ OLD COATS RD/
 L@ OAK GROVE CHURCH RD/ CONT STRAIGHT
 ONTO GUY RD

SUBDIV:
 PHONE :
 PHONE : (919) 779-3705

STRUCTURE: 000 000 30X27 SITTING ROOM

FLOOD ZONE : FLOOD ZONE X
 SEPTIC - EXISTING? : EXISTING
 WATER SUPPLY : WELL

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/16	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002867927
	9/08/16	AP	T/S: 09/07/2016 11:45 AM JFORBES ----- T/S: September 08, 2016 11:19 AM BSUTTON -----
B103 01	9/15/16	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002871887
	9/15/16	DA	T/S: 09/14/2016 12:53 PM LBENNETT ----- T/S: September 15, 2016 11:14 AM BSUTTON ----- Foundation is off the footing on back wall for aprox 5 feet. Dig out, pin with #4 rebar every 12 inches and leave open for inspection. Will check at open floor.
B103 02	9/16/16	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002872448
	9/16/16	AP	T/S: 09/15/2016 01:10 PM JBROCK ----- T/S: September 16, 2016 11:00 AM BSUTTON -----
B105 01	9/21/16	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002874188
	9/21/16	AP	T/S: 09/20/2016 12:46 PM JFORBES ----- T/S: September 21, 2016 07:48 AM BSUTTON -----
R125 01	10/12/16	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002884815
	10/12/16	AP	T/S: 10/13/2016 01:27 PM JFORBES ----- T/S: 10/13/2016 01:27 PM JFORBES -----
R131 01	11/18/16	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 002899938
	<u>11/18/16</u>	<u>AP DT</u>	T/S: 11/17/2016 08:09 AM JFORBES -----

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	10/12/16	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002884823
	10/12/16	AP	T/S: 10/13/2016 01:28 PM JFORBES ----- T/S: 10/13/2016 01:28 PM JFORBES -----
R131 01	11/18/16	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 002899946
	<u>11/18/16</u>	<u>AP DT</u>	T/S: 11/17/2016 08:09 AM JFORBES -----

COMMENTS AND NOTES