

## Harnett County

Inspections  
420 McKinney Pkwy  
Lillington , NC 27546

Phone: 910-893-7525  
Fax: 910-893-2793

### Inspection Report

**Permit:** CARE16-50039763

**OWNER:** BRACKLEY ROBERT E JR & SUSAN

**Site Address:** 464 BLUFF RIDGE LN ANGIER, NC 27501

Harnett County Inspections Department

Inspection Type: ROUGH IN

Inspection Date: 06/15/2021

Result: DISAPPROVED

Remarks:

Notes: 1. Fire block all lowered ceilings. 2. Fire Stop all penetrations of pipe and wiring through top and bottom plates. 3. Protect plumbing and wiring within 1.5 inches of face of studs with nail plates. Ok to insulate

All violations are subject to reinspection fees at the inspectors discretion.

**Brad Sutton**  
Inspector